

May 2025

DAY	ELEV	STORAGE ACRE-FEET		COMPUTED*	CCWA	PRECIP ON	RELEASE - AF.				EVAPORATION		PRECIP
		IN LAKE	CHANGE	INFLOW AF.	INFLOW AF.	RES. SURF. AF.	TUNNEL	HILTON CREEK	OUTLET	SPILLWAY	AF.	INCH	INCHES
	744.73	168,741											
1	744.70	168,656	-85	27.6	0.0	0.0	59.5	13.3	15.0	0.0	24.8	0.130	0.00
2	744.68	168,599	-57	29.8	0.0	11.8	50.3	13.3	14.0	0.0	21.0	0.110	0.05
3	744.66	168,542	-57	41.1	0.0	0.0	43.1	13.3	15.0	0.0	26.7	0.140	0.00
4	744.62	168,428	-114	-18.3	0.0	2.4	39.4	13.2	15.0	0.0	30.5	0.160	0.01
5	744.61	168,400	-28	64.2	0.0	0.0	31.6	13.2	15.0	0.0	32.4	0.170	0.00
6	744.58	168,316	-84	21.1	0.0	0.0	36.8	13.3	15.0	0.0	40.0	0.210	0.00
7	744.55	168,232	-84	30.9	0.0	0.0	42.9	13.2	15.0	0.0	43.8	0.230	0.00
8	744.53	168,176	-56	47.3	0.0	0.0	40.8	13.3	15.0	0.0	34.2	0.180	0.00
9	744.50	168,092	-84	41.2	0.0	0.0	46.6	13.2	16.0	0.0	49.4	0.260	0.00
10	744.47	168,008	-84	46.2	0.0	0.0	44.1	13.2	14.0	0.0	58.9	0.310	0.00
11	744.44	167,923	-85	74.0	0.0	0.0	43.4	13.2	15.0	0.0	87.4	0.460	0.00
12	744.40	167,811	-112	17.7	0.0	0.0	44.5	13.2	15.0	0.0	57.0	0.300	0.00
13	744.36	167,699	-112	12.3	0.0	0.0	43.0	13.2	15.0	0.0	53.1	0.280	0.00
14	744.31	167,559	-140	-15.2	0.0	0.0	48.3	13.2	14.0	0.0	49.3	0.260	0.00
15	744.27	167,446	-113	18.9	0.0	0.0	58.2	13.2	15.0	0.0	45.5	0.240	0.00
16	744.22	167,306	-140	7.4	0.0	0.0	71.8	13.2	15.0	0.0	47.4	0.250	0.00
17	744.19	167,194	-112	24.0	0.0	2.3	72.2	13.2	15.0	0.0	37.9	0.200	0.01
18	744.14	167,082	-112	20.9	0.0	0.0	66.9	13.2	15.0	0.0	37.8	0.200	0.00
19	744.10	166,969	-113	2.5	0.0	0.0	40.0	13.2	15.0	0.0	47.3	0.250	0.00
20	744.06	166,857	-112	8.2	0.0	0.0	49.5	13.2	14.0	0.0	43.5	0.230	0.00
21	744.01	166,717	-140	2.1	0.0	0.0	57.2	13.2	15.0	0.0	56.7	0.300	0.00
22	743.98	166,633	-84	89.2	0.0	0.0	63.8	13.2	15.0	0.0	81.2	0.430	0.00
23	743.93	166,492	-141	14.0	0.0	0.0	66.4	13.2	15.0	0.0	60.4	0.320	0.00
24	743.88	166,352	-140	1.9	0.0	0.0	66.6	13.2	15.0	0.0	47.1	0.250	0.00
25	743.84	166,240	-112	35.2	0.0	0.0	65.3	13.2	14.0	0.0	54.7	0.290	0.00
26	743.79	166,099	-141	-6.7	0.0	0.0	66.7	13.1	15.0	0.0	39.5	0.210	0.00
27	743.75	165,987	-112	34.8	0.0	0.0	71.6	13.1	15.0	0.0	47.1	0.250	0.00
28	743.71	165,875	-112	9.0	9.6	0.0	59.1	13.2	15.0	0.0	43.3	0.230	0.00
29	743.67	165,763	-112	-4.8	11.9	0.0	58.2	13.1	14.0	0.0	33.8	0.180	0.00
30	743.64	165,678	-85	42.3	11.9	0.0	60.4	13.1	15.0	0.0	50.7	0.270	0.00
31	743.61	165,595	-83	36.8	11.9	0.0	59.5	13.1	14.0	0.0	45.1	0.240	0.00
TOTALS			-3,146	755.6	45.3	16.5	1,667.7	409.2	459.0	0.0	1,427.5	7.540	0.07
AVERAGE		167,249											

Comments: *Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and CCWA inflow.
Indicated outlet release includes leakage from outlet valves and spillway gates.
Data based on a 24 hour period ending 0800.

