



October 2024

DAY	ELEV	STORAGE ACRE-FEET		COMPUTED*	CCWA	PRECIP ON	RELEASE - AF.				EVAPORATION		PRECIP
		IN LAKE	CHANGE	INFLOW AF.	INFLOW AF.	RES. SURF. AF.	TUNNEL	HILTON CREEK	OUTLET	SPILLWAY	AF.	INCH	INCHES
	748.95	180,979											
1	748.91	180,859	-120	25.2	0.0	0.0	56.2	13.6	42.0	0.0	33.4	0.180	0.00
2	748.87	180,740	-119	41.4	0.0	0.0	59.3	13.6	43.0	0.0	44.5	0.240	0.00
3	748.82	180,591	-149	17.4	0.0	0.0	60.6	13.6	44.0	0.0	48.2	0.260	0.00
4	748.77	180,442	-149	19.8	0.0	0.0	61.2	13.6	44.0	0.0	50.0	0.270	0.00
5	748.73	180,323	-119	33.4	0.0	0.0	63.3	13.6	44.0	0.0	31.5	0.170	0.00
6	748.67	180,144	-179	-12.4	0.0	0.0	60.9	13.6	44.0	0.0	48.1	0.260	0.00
7	748.64	180,055	-89	44.6	0.0	0.0	36.3	13.6	43.0	0.0	40.7	0.220	0.00
8	748.60	179,936	-119	8.0	0.0	0.0	45.4	13.6	44.0	0.0	24.0	0.130	0.00
9	748.55	179,789	-147	-10.1	0.0	0.0	46.0	13.6	44.0	0.0	33.3	0.180	0.00
10	748.51	179,671	-118	8.3	0.0	2.5	44.8	13.6	39.0	0.0	31.4	0.170	0.01
11	748.46	179,524	-147	-23.6	0.0	2.5	45.8	13.6	37.0	0.0	29.5	0.160	0.01
12	748.42	179,407	-117	6.9	0.0	4.9	45.9	13.5	38.0	0.0	31.4	0.170	0.02
13	748.37	179,259	-148	-38.3	0.0	0.0	47.9	13.6	39.0	0.0	9.2	0.050	0.00
14	748.32	179,112	-147	-18.5	0.0	0.0	35.4	13.6	39.0	0.0	40.5	0.220	0.00
15	748.30	179,053	-59	50.3	0.0	0.0	38.5	13.5	37.0	0.0	20.3	0.110	0.00
16	748.27	178,965	-88	15.9	0.0	4.9	37.0	13.5	38.0	0.0	20.3	0.110	0.02
17	748.22	178,818	-147	-41.2	0.0	2.5	39.7	13.5	33.0	0.0	22.1	0.120	0.01
18	748.18	178,700	-118	-0.8	0.0	0.0	41.2	13.6	33.0	0.0	29.4	0.160	0.00
19	748.14	178,583	-117	3.9	0.0	0.0	47.8	13.5	32.0	0.0	27.6	0.150	0.00
20	748.09	178,406	-177	-52.5	0.0	0.0	49.5	13.6	32.0	0.0	29.4	0.160	0.00
21	748.05	178,318	-88	38.6	0.0	0.0	45.4	13.5	31.0	0.0	36.7	0.200	0.00
22	748.00	178,171	-147	-20.4	0.0	0.0	48.1	13.5	32.0	0.0	33.0	0.180	0.00
23	746.96	175,133	-3,038	-2,908.4	0.0	0.0	56.9	13.5	32.0	0.0	27.2	0.150	0.00
24	747.91	177,906	2,773	2,909.2	0.0	0.0	58.7	13.5	31.0	0.0	33.0	0.180	0.00
25	747.86	177,759	-147	-12.4	0.0	0.0	60.1	13.5	28.0	0.0	33.0	0.180	0.00
26	747.82	177,641	-118	11.1	0.0	0.0	60.1	13.5	28.0	0.0	27.5	0.150	0.00
27	747.78	177,523	-118	16.1	0.0	0.0	62.5	13.5	27.0	0.0	31.1	0.170	0.00
28	747.73	177,376	-147	-39.2	0.0	0.0	61.8	13.5	27.0	0.0	5.5	0.030	0.00
29	747.68	177,229	-147	-10.3	0.0	0.0	61.6	13.4	27.0	0.0	34.7	0.190	0.00
30	747.64	177,111	-118	9.0	0.0	0.0	61.8	13.5	28.0	0.0	23.7	0.130	0.00
31	747.58	176,936	-175	-58.1	0.0	0.0	62.1	13.4	25.0	0.0	16.4	0.090	0.00
TOTALS			-4,043	12.9	0.0	17.3	1,601.8	419.8	1,105.0	0.0	946.6	5.140	0.07
AVERAGE		178,822											

Comments: *Computed inflow is the sum of change in storage, releases and evaporation minus precip on the reservoir surface and CCWA inflow.
 Indicated outlet release includes leakage from outlet valves and spillway gates.
 Data based on a 24 hour period ending 0800.

