



May 2024

DAY	ELEV	STORAGE		COMPUTED* INFLOW C.F.S.	RELEASE - C.F.S.			PUMPING PLANT	EVAPORATION		PRECIP INCHES
		1000 ACRE-FEET			RIVER				C. F. S.	INCHES	
		IN LAKE	CHANGE	POWER	SPILL	OUTLET					
		848.9									
1	454.44	851.6	2.7	5,692	3,482	598	0	137	97	0.28	0.00
2	454.74	854.8	3.2	5,843	4,027	0	0	146	80	0.23	0.00
3	455.01	857.6	2.8	5,943	4,260	1	0	156	94	0.27	0.00
4	455.56	863.4	5.8	7,102	4,026	5	0	139	0	0.00	0.98
5	456.07	868.8	5.4	6,565	3,663	0	0	115	67	0.19	0.00
6	456.32	871.5	2.7	5,643	3,875	246	0	119	63	0.18	0.00
7	456.45	872.9	1.4	5,053	3,581	560	0	123	92	0.26	0.00
8	456.66	875.1	2.2	5,510	3,521	582	0	130	152	0.43	0.00
9	457.06	879.3	4.3	6,396	3,958	0	0	176	117	0.33	0.00
10	457.52	884.3	4.9	6,861	4,058	9	0	199	117	0.33	0.00
11	457.94	888.7	4.5	6,939	4,368	9	0	189	110	0.31	0.00
12	458.42	893.9	5.2	6,888	3,996	0	0	184	110	0.31	0.00
13	458.94	899.5	5.6	7,138	4,026	0	0	185	111	0.31	0.00
14	459.47	905.2	5.7	7,277	4,099	0	0	194	100	0.28	0.00
15	459.94	910.3	5.1	6,944	4,075	2	0	196	111	0.31	0.00
16	460.36	914.8	4.6	6,666	4,076	0	0	199	94	0.26	0.00
17	460.62	917.7	2.8	6,580	3,996	876	0	202	83	0.23	0.00
18	460.77	919.3	1.6	6,432	4,510	824	0	205	72	0.20	0.00
19	460.98	921.6	2.3	6,410	4,104	882	0	203	72	0.20	0.00
20	461.16	923.5	2.0	6,326	5,016	0	0	212	108	0.30	0.00
21	461.38	925.9	2.4	5,925	4,214	0	176	202	123	0.34	0.00
22	461.51	927.4	1.4	5,032	3,862	0	149	208	98	0.27	0.00
23	461.78	930.3	2.9	5,535	3,723	0	0	214	112	0.31	0.00
24	461.80	930.5	0.2	4,049	3,479	140	0	211	109	0.30	0.00
25	461.91	931.7	1.2	3,777	2,878	0	0	214	80	0.22	0.00
26	461.88	931.4	-0.3	3,306	3,171	0	0	217	83	0.23	0.00
27	461.98	932.5	1.1	4,101	3,228	0	0	220	102	0.28	0.00
28	462.18	934.7	2.2	4,202	2,760	0	0	224	112	0.31	0.00
29	462.20	934.9	0.2	3,288	2,809	0	0	238	131	0.36	0.00
30	462.36	936.7	1.8	3,932	2,705	0	0	233	109	0.30	0.00
31	462.48	938.0	1.3	4,017	2,985	0	0	237	131	0.36	0.00
<b>TOTALS</b>			<b>89.2</b>	<b>175,372</b>	<b>116,531</b>	<b>4,734</b>	<b>325</b>	<b>5,827</b>	<b>3,040</b>	<b>8.49</b>	<b>0.98</b>
<b>ACRE-FEET</b>			<b>89,200</b>	<b>347,850</b>	<b>231,139</b>	<b>9,390</b>	<b>645</b>	<b>11,558</b>	<b>6,030</b>		

\* COMPUTED INFLOW IS THE SUM OF CHANGE IN STORAGE, RELEASES, PUMPING AND EVAPORATION

**SUMMARY**

Release (ACRE-FEET)				Precipitation	
Power	231,139	Outlet	645	This month =	0.98
Spill	9,390	Pumping Plant	11,558	October 01, 2023 To date =	20.57
Total =		252,732			