

# Appendix A: Response to Comments



Connor, Mary &lt;mconnor@usbr.gov&gt;

---

**Clark's Fork Reclamation District # 2069 response to proposed Water conveyance**

1 message

**Ron Allvin** <ronallvin@outlook.com>

Fri, Jul 14, 2017 at 12:07 PM

To: "mconnor@usbr.gov" &lt;mconnor@usbr.gov&gt;

Allvin-1 | Please be advised the our District is requesting a copy of the indicated EIR and hereby assert that before any water leaves the

Kings River Water Service Area we believe that the lower river be first in line for water resources before satisfying this proposal. Please include this information in the appropriate public comments section prior to any and all action completion. Thank you for your consideration.

Virus-free. [www.avast.com](http://www.avast.com)

## Reclamations Response to Comments

**Allvin - 1** Reclamation provided an Environmental Assessment pursuant to the National Environmental Policy Act for public review. Reclamation does not prepare EIR documents pursuant to California Environmental Quality Assessments.

Additional language has been added to page 12 of the EA. Pursuant to the agreement made effective May 26, 2005 by and between the Water Association and Westlands, Westlands may divert Available Water from the Mendota Pool when and as such Available Water is present. For purposes of this Agreement, Available Water shall be deemed to be “present in the Mendota Pool” when, but only when, the amount of water flowing in the Kings River channel below Pine Flat Dam is such that (i) all members of the Water Association are able to meet their then current water demands within the defined Kings River Service Area. (ii) Pursuant to certain Permanent High-Flow Channel Agreement by and between the Water Association and the Kings County Water District dated August 6, 1985, and any similar obligations imposed upon the Water Association and/or members of the Water association pursuant to licenses granted by the State Water Resources Control Board with respect to the use of Kings River water, are then being satisfied, and (iii) water is leaving the Kings River Service Area via the Fresno Slough channel and flowing into the Mendota Pool. Prior to initiation any diversion of Available Water, Westlands shall notify the Water Association Watermaster. The Water Association consents to Westlands’ diversion of the Available Water under the terms and conditions of this agreement.

The comment letter has been included in the appropriate section of the final EA.



Connor, Mary &lt;mconnor@usbr.gov&gt;

---

**Info request**

1 message

**Carol & James Verboon** <vboonfrms@sti.net>

Fri, Jul 14, 2017 at 12:35 PM

To: mconnor@usbr.gov

Cc: Ron Allvin &lt;ronallvin@outlook.com&gt;

Dear Ms. Kate Connor,

in regards to Title:

Verboon-1 Westlands Water District 5-year Warren Act Contract for Kings River Flows in the San Luis Canal. I request a detailed description of what constitutes "flood flows" on the Kings River. I also could find no environmental assessment regarding impacts to Kings River water users or habitat. Please forward any info you have regarding the above requests.

Thank you for your time and consideration.

Sincerely,

Jim Verboon

## Reclamations Response to Comments

**Verboon– 1** Additional language has been added to page 12 of the EA from time to time, significant runoff from the Kings River results in the temporary availability of Kings River water in excess of the demands of the members of the Water Association (the “Available Water”). By virtue of the Water Rights, the Water Association has consistently claimed title to all water flowing in the Kings River and has previously opposed attempts by third parties to divert Kings River water without the Water Association’s consent. The Water Association therefore claims title to the Available Water by virtue of the Water Rights. Pursuant to the agreement made effective May 26, 2005 by and between the Water Association and Westlands, Westlands may divert Available Water from the Mendota Pool when and as such Available Water is present. For purposes of this Agreement, Available Water shall be deemed to be “present in the Mendota Pool” when, but only when, the amount of water flowing in the Kings River channel below Pine Flat Dam is such that (i) all members of the Water Association are able to meet their then current water demands within the defined Kings River Service Area. (ii) Pursuant to certain Permanent High-Flow Channel Agreement by and between the Water Association and the Kings County Water District dated August 6, 1985, and any similar obligations imposed upon the Water Association and/or members of the Water association pursuant to licenses granted by the State Water Resources Control Board with respect to the use of Kings River water, are then being satisfied, and (iii) water is leaving the Kings River Service Area via the Fresno Slough channel and flowing into the Mendota Pool. Prior to initiation any diversion of Available Water, Westlands shall notify the Water Association Watermaster. The Water Association consents to Westlands’ diversion of the Available Water under the terms and conditions of this agreement.

On page 12 of the Draft EA Reclamation analyzes the introduction of Kings River flood flows into the canal as flows are available. The Proposed Action would only occur under flood conditions. There would be no impacts to Kings River Users and/or habitat pursuant to this agreement.

# **Appendix B: San Luis Canal 2017 Draft Water Quality Monitoring Plan**

# RECLAMATION

*Managing Water in the West*

## San Luis Canal Non-Project Water Pump-in Program 2017 Water Quality Monitoring Plan

---



U.S. Department of the Interior  
Bureau of Reclamation  
Mid-Pacific Region  
South-Central California Area Office

Revised: 27 July 2017

## Mission Statements


The mission of the Department of the Interior is to protect and provide access to our Nation's natural and cultural heritage and honor our trust responsibilities to Indian Tribes and our commitments to island communities.


The mission of the Bureau of Reclamation is to manage, develop, and protect water and related resources in an environmentally and economically sound manner in the interest of the American public.



## List of Abbreviations and Acronyms

|                         |   |
|-------------------------|---|
| COC                     | chain of custody  |
| CVP                     | Central Valley Project  |
| DWR                     | California Department of Water Resources  |
| EC                      | electrical conductivity, $\mu\text{S}/\text{cm}$                                      |
| Lateral 7               | Westlands Water District facility connected to the San Luis Canal at Milepost 115.43L |
| mg/L                    | milligrams per liter, equivalent to parts per million                                 |
| QA                      | Quality Assurance   |
| QC                      | Quality Control   |
| QCO                     | Quality Control Officer   |
| Reclamation             | U.S. Department of the Interior, Bureau of Reclamation                                |
| San Luis Canal          | the federal portion of the California Aqueduct  |
| Check 13                | San Luis Canal Milepost 66.74, O'Neill Forebay  |
| Check 21                | San Luis Canal Milepost 172.44, near Kettleman City                                   |
| TDS                     | Total dissolved solids, mg/L  |
| Title 22                | California Drinking Water Standards   |
| $\mu\text{g}/\text{L}$  | micrograms per liter, equivalent to parts per billion                                 |
| $\mu\text{S}/\text{cm}$ | microSiemens per cm, salinity in water  |
| Westlands or District   | Westlands Water District  |





**Legend**

- ☆ City
- San Luis Canal
- San Luis Drain
- WWD Boundary
- 1998 Agreement Final Settlement
- Town / Range

**WWD Acquired Lands**

- Britz Peak Settlement
- Broadview Water District
- Sigausse Settlement
- L.N.A.S.

**SLC Canal Injection Location**

- 2014 Location
- Possible Future Location

**Groundwater Source**

- 2014 Participant
- Possible Future Participant
- Part Participant

**WESTLANDS WATER DISTRICT**  
 1500 WESTLANDS AVENUE, SUITE 100  
 WESTLANDS, CALIFORNIA 94593  
 PHONE: (925) 255-2400 FAX: (925) 255-2401  
 WWW.WESTLANDSWATERDISTRICT.COM

**LOCATIONS OF GROUNDWATER WELLS**  
 SLC INJECTION LOCATION

DATE DRAWN: 10/24/14  
 DRAWING NO.: 2114-M-0008  
 DRAWN BY: J. JANSSEL  
 CHECKED BY: J. JANSSEL

0 1 2 4 6 8 10 Miles



# San Luis Canal

## Non-Project Water Pump-in Program

### 2017 Water Quality Monitoring Plan

---

#### **Introduction**

The overall supply of Central Valley Project (CVP) water has been reduced by drought and restrictions on pumping from the Sacramento-San Joaquin Delta. Under the Warren Act of 1911, Reclamation may execute temporary contracts to convey non-project water in excess capacity in federal irrigation canals.

In 2017, Reclamation will execute a five-year Warren Act contract with Westlands Water District (Westlands) to pump non-project water into the San Luis Canal to supplement the diminished supply of CVP water for its farmers. The non-project water will come from wells located beside the canal and wells located around the Mendota Pool. This would occur in years when the CVP allocation to Westlands is 20 percent or less, and generally between April 1 and August 31.

On rare occasions, flood water from the Kings River may be pumped into the canal. This would help with flood control in the Mendota area.

The non-project water would either be directly delivered to agricultural users in Westlands from the canal or exchanged for CVP water stored in San Luis Reservoir for later delivery to Westlands.

The San Luis Canal is jointly owned and operated by the United States and the State of California. The federal portion provides water for irrigation to the San Luis Unit between Santa Nella and Kettleman City, California. The State portion provides water mainly for municipal and industrial use in the Los Angeles basin. Consequently, the addition of non-project water must not cause any problems for downstream users. Water quality monitoring is an important component of this program.

The 2017 San Luis Canal Non-Project Water Monitoring Program fundamental assumptions:

1) All sources of non-project water must comply with California Drinking Water standards (Title 22)<sup>1</sup>. No in-canal dilution is allowed.

---

<sup>1</sup> California Code of Regulations, Title 22. The Domestic Water Quality and Monitoring Regulations specified by the State of California Health and Safety Code (Sections 4010 4037), and Administrative Code (Sections 64401 et seq.), as amended.  
[http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/documents/lawbook/dwregulations-2017-04-10.pdf](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/documents/lawbook/dwregulations-2017-04-10.pdf)

2) Each source of non-project water must be tested regularly to confirm that it is consistent, predictable, and acceptable in quality.

3) Reclamation and DWR will use real-time monitoring of salinity and turbidity in water in the canal to identify any problems caused by the addition of the non-project water.

This document describes the plan for measuring the changes in the quality of water in the San Luis Canal caused by the conveyance of this non-project water, plus changes in groundwater elevation to estimate subsidence.

This document has been prepared by the U.S. Department of the Interior, Bureau of Reclamation (Reclamation), in cooperation with the California Department of Water Resources (DWR) and the State Water Contractors.

## **Background**

The federal Central Valley Project (CVP) delivers water to almost a million acres of farmland in the San Joaquin Valley of California. The CVP is also the sole source of clean water for several cities and for state, federal, and private wildlife areas in central California.

This water is suitable in quality for irrigation, wetlands, and domestic use. The region is regularly affected by droughts that drastically reduce the supply of water. Environmental regulations also restrict the operation of the federal and state pumping plants to divert water from the delta. The salinity of water in the Delta is highly variable due to the influence of tides and outflow of river water.

The source of CVP water for the western San Joaquin Valley is the Sacramento River conveyed through the Delta through the Delta-Mendota Canal. CVP water is pumped from this canal into the O'Neill Forebay and pumped again into San Luis Reservoir. CVP water is released back into the O'Neill Forebay and into the San Luis Canal.

The San Luis Canal is 102.5 miles long with a capacity ranging from 13,100 cfs at Check 13 (O'Neill Forebay) to 8,100 cfs at Check 21 (Kettleman City). This is the federal section of the California Aqueduct.

The canal continues southerly past Check 21 to deliver water to the State Water Contractors in southern California, mainly for municipal and industrial purposes. The Kern National Wildlife Refuge receives water indirectly from the canal in Kern County near Check 29 of the California Aqueduct.

Westlands Water District (Westlands) is the largest contractor for CVP water. Most the water from the San Luis Canal is delivered to farms across Westlands through buried

pressurized pipelines or “laterals”. CVP water is also delivered to Panoche, Pacheco, and San Luis Water Districts mainly for agricultural use.

WWD Lateral 7 is a buried pressurized pipeline connected to the San Luis Canal at Milepost 115.43L. The eastern end of Lateral 7 is connected to an open ditch that is linked to the Mendota Pool, south of the Mendota Wildlife Management Area. Water can be conveyed in this lateral in both directions.

During the drought years of 2014 and 2015, groundwater from wells around the Mendota Pool was pumped through Lateral 7 into the San Luis Canal. Some groundwater was pumped from wells directly into the canal as well. During spring 2017, flood water from the Kings River was pumped through Lateral 7 into the canal.

The Warren Act of 1911<sup>2</sup> authorizes Reclamation to execute temporary contracts to impound, store, and carry non-project water in federal irrigation canals when excess capacity is available. The Central Valley Project Improvement Act of 1992<sup>3</sup> allows Reclamation to negotiate other agreements which allow transfers of CVP water for non-project groundwater and conserved water.

As stated before, the CVP supply of water is limited by drought and environmental regulations. Farmers must use groundwater to supplement their limited supply of CVP water. The quality of local groundwater is variable and can have high concentrations of salts and trace metals. Many fields and orchards are not located near wells or the Mendota Pool. The 2017 San Luis Canal Non-Project Water Pump-in Program will help local farmers distribute water to remote crops and orchards across Westlands and other San Luis Unit districts.

There are three main sources of non-project water:

- 1) Groundwater pumped from wells beside the canal (Canal Integration Program);
- 2) Groundwater from wells beside the Mendota Pool, conveyed through Lateral 7 to the canal at Milepost 115.43L; and
- 3) Floodwater from the Kings River conveyed through Lateral 7 to the canal.

Our main concerns are

- 1) The potential degradation of water quality in the San Luis Canal with the addition of this non-project water, and
- 2) Possible, irreversible damage to CVP and district facilities through subsidence from continuous pumping of these wells.

---

<sup>2</sup> Act of February 21, 1911, ch. 141, 36 Stat. 925

<sup>3</sup> Section 3405(a) of the Central Valley Project Improvement Act (CVPIA) (Title 34 of Public Law 102-575)

We will ask for sufficient information about each well to confirm that the pumped groundwater will be consistent, predictable, and acceptable in quality.

We will monitor the quality of the raw water in Lateral 7. Previous data indicate that flood water will be comparable to water in the canal, with low salinity and variable turbidity. Groundwater will tend to be higher in salinity and other minerals than the water in the canal.

We will monitor water quality in the canal upstream and downstream of the discharge from this lateral with field measurements and grab samples.

We will use real-time measurements of salinity and turbidity to track daily conditions in the canal. We will use routine monthly monitoring by DWR at Checks 13 and 21 to identify changes.

Reclamation will execute a general license with the San Luis Unit districts to install, operate, and maintain pump-in facilities across the canal embankment. Each discharge facility will have a totalizing flow meter, a corporation stop for calibration, and a spigot for water sample collection.

Staff from Westlands and DWR will calibrate flow meters on each point of discharge into the canal, and will record the volume pumped into the canal. Multiple wells may pump into the same discharge facility.

Staff from Westlands will coordinate all analyses of non-project water for this monitoring program, and compile all flow and water quality data for each source of non-project water. We will ask for depth to groundwater measurements in every participating well.

Reclamation will review these data to estimate contaminant loading in the canal, to confirm that the water in the canal is safe for downstream water users, to prevent subsidence, and to determine the feasibility of continuing this program in the future. All data will be shared with DWR and the State Water Contractors.

## **Monitoring Mission and Goals**

The mission of this monitoring program is to produce physical measurements that will determine the changes in the quality of the water in San Luis Canal caused by the conveyance of non-project water. The data will be used to administer the terms of Warren Act Contracts and other exchange agreements, and to ensure that the quality of CVP water is suitable for downstream water users. The monitoring program will also measure changes to groundwater resources to prevent subsidence problems to local facilities.

## **Program Goals**

The general goals of monitoring are:

- Evaluate the quality of water in each source of non-project water;
- Confirm that the blend of CVP water and non-project water in the San Luis Canal is suitable for all downstream users;
- Provide reliable data for administration of the contracts and agreements; and
- Provide measurements of depth to groundwater to prevent subsidence.

## **Study Area**

The Study Area is the San Luis Canal from the O'Neill Forebay (Check 13) to Kettleman City (Check 21). It is the federal portion of the California Aqueduct.

The study area includes the Mendota Pool, Fresno Slough, and Westlands Lateral 7.

## **Water Quality Standards**

All non-project water must meet California Drinking Water Standards (Title 22) before entering the canal. These constituents are listed in **Table 5**. This should be conducted every three years.

Each discharge of non-project water must be tested for a short list of constituents to confirm that the water is consistent, predictable, and acceptable in quality. The short list was developed to comply with the California Department of Water Resources (DWR) policy for acceptance of non-project water into the State Water Project.

The short list measurements must be conducted weekly during the first month of operation, then monthly for the duration of pumping. The short list may be modified to add constituents. If the concentration of a constituent is consistently less than minimum laboratory detection level, we may drop it from the short list.

The non-project water must meet the Title 22 standards before entering the canal. No dilution in the canal will be allowed.

Reclamation, in coordination with DWR and the State water Contractors, may allow minor exceedances of certain secondary Title 22 constituents such as turbidity, if all primary standards are met.



## **Water Quality Monitoring Plan**

### **Groundwater from Wells beside the San Luis Canal (Canal Integration Program)**

#### **Baseline Tests of Individual Wells**

**Table 4** is a short list of constituents of concern to be measured in each well each year before pumping into the canal to screen out non-compliant wells<sup>4</sup>. Wells that do not meet this short list may not participate in the 2017 Pump-in Program.

Each well must be tested every three years for all of the constituents listed in **Table 5** before pumping in the San Luis Canal. Each report must clearly identify the location of the well.

All new wells proposed to participate in the 2017 pump-in program must be approved Reclamation prior to discharging any groundwater into the San Luis Canal.

#### **Routine Tests of Individual Wells**

Each well weekly during the first four weeks of pumping for the short list of constituents (**Table 4**), then monthly while actively pumping into the San Luis Canal to confirm that the water quality is consistent, predictable, and reliable.

The short list may be modified to add constituents of concern or drop non-detected constituents.

All water quality analyses should be conducted by a laboratory listed in **Table 6**. All water samples must be sampled and preserved according to established protocols in correct containers. Each sample of well water must be analyzed at the expense of the well owner.

The costs of sampling and analysis of all non-project water will be borne by the well operators.

Reclamation will allow the introduction of water from two or more wells through one discharge point if the blended water meets the Title 22 standards. Special monitoring may be required for these situations.

We will need the following information prior to pumping groundwater into the canal:

- the location of each well, pumping rate, and point of discharge into the San Luis Canal;
- complete Title 22 water quality analyses for each well

---

<sup>4</sup> Reclamation will provide instructions for sampling groundwater.

- the depth to groundwater in each well before pumping into the San Luis Canal commences

Most of the wells are privately owned, so we will need assistance from Westlands' staff to provide access to each well for Reclamation and DWR staff.

When the Project is operating, Westlands will provide DWR and Reclamation with weekly schedules which identify the flow from the active wells.

Westlands will provide weekly updates identifying the current and anticipated water quality changes within the SLC by using the daily model. The goal is to provide Reclamation and the State Water Project Facilitation Group with a day-to-day prediction of downstream water quality using real-time pump-ins, real-time upstream background flows, and current background water quality data.

## **Lateral 7 Monitoring**

The water flowing through Lateral 7 may originate in many wells around the Mendota Pool or flood water from the Kings River. It would be impractical to monitor every well for this program, so we will focus on the composite water that is pumped into the Lateral.

Samples should be collected from the Lateral at the Adams Avenue pump station.

All water pumped into the San Luis Canal from Lateral 7 must be tested for the short list of constituents before pumping into the canal commences, then weekly for the first four weeks, then monthly for the duration of pumping.

The Lateral 7 water must be tested for the full suite of Title 22 constituents once a year while pumping into the canal occurs.

Please refer to Appendix B for more information about Lateral 7 monitoring.

## **Compliance Monitoring**

### **Daily Salinity and Turbidity in the San Luis Canal**

Mean daily salinity and turbidity will be measured with the DWR sensors that report real-time data to CDEC. Westlands and Reclamation will download daily average data for San Luis Canal Checks 13 and 21 to measure changes in the canal between these checks that may be attributable to the addition of the non-project water.

Westlands and Reclamation will use mass balance models to estimate the contribution of salinity to the canal from the actively pumping wells and Lateral 7, and compare this with the real-time data.

If the addition of the non-project water is increasing the salinity of water in the canal more than 100 uS/cm, Reclamation will work with Westlands and the well operators to turn off high salinity wells.

If the addition of the non-project water from Lateral 7 is increasing the turbidity of water in the canal more than 10 NTU, Reclamation will work with Westlands to reduce discharge from the lateral. Note: Turbidity is generally not a problem in groundwater.

Westlands will run model simulations to quantify anticipated improvements in conductivity with the termination of pumping from specific wells. The participating wells with the highest salinity will be targeted first, continuing to the wells with the lowest concentrations until canal water quality stabilizes or improves. As salinity at Check 21 improves, wells will be brought on-line to commence pumping.

### **Flow Monitoring of Non-Project Water**

Westlands and DWR field staff will calibrate the flow meters for each discharge point and report the monthly volume of water pumped into the canal.

### **Routine Water Quality Monitoring – San Luis Canal**

DWR will collect monthly grab samples at Checks 13 (KA007089) and 21 (KA017226) to measure trace metals and other minerals in the canal water. The data will be posted here:

[http://www.water.ca.gov/waterdatalibrary/waterquality/station\\_group/select\\_station.cfm](http://www.water.ca.gov/waterdatalibrary/waterquality/station_group/select_station.cfm)

Reclamation will review these results to identify changes and will determine if they are caused by the addition of the non-project groundwater.

### **Routine Water Quality Monitoring – Lateral 7**

Non-project water from the Mendota Pool Kings River will be pumped into the San Luis Canal from Westlands Lateral 7. Reclamation may take grab samples to confirm the short list results collected by the District.

Reclamation may make field measurements of water in the lateral and from the canal upstream and downstream of Milepost 115.43L.

### **DWR Monitoring of Wells**

DWR may collect samples for water quality testing for any constituents of concern from any Westlands source well or at any point of water entry into the Aqueduct for testing. DWR will use Bryte Chemical Laboratory for all DWR well sample analyses and the data will be available to Westlands for review. If any well tested by DWR is found to exceed

the identified MCL's, Reclamation will direct the District to stop pumping pending resampling and retesting by an independent laboratory.

Westlands will coordinate with well operators to provide access for DWR personnel to conduct any of the following activities on private property within WWD's service area during the term of this Proposal:

- Verification of metering calibration standards and requirements for flow meters located at the point of entry into the Aqueduct and at the point of delivery out of the Aqueduct,
- Collection of water samples from source wells and at the point of pump-in to the Aqueduct for testing of water quality,
- Any other activities deemed necessary by DWR to comply with the terms of this Proposal.

### **Depth to Groundwater**

Westlands staff will measure the initial depth to groundwater in each well before pumping into the canal, and twice a year while the 2017 Warren Act is in effect. The current depth to groundwater in each well will be compared to the initial depth measurement. If the current depth is more than 25 feet below the initial depth, Reclamation advise the District that pumping from that well be stopped until the depth recovers to an agreed upon depth.

### **Data Compilation and Review**

All flow and water quality data collected by Westlands will be presented each month to Reclamation and DWR via e-mail. Reclamation will review the data to identify changes in the quality of water in the canal and in individual wells, and potential changes in the local aquifer that could lead to overdraft or subsidence. Reclamation, in consultation with DWR, will direct WWD on the continuation of pumping of groundwater into the San Luis Canal.

### **Water Quality Monitoring Parameters and Data Management**

The following sections describe the parameters for real-time and laboratory measurement of water quality, as well as methods for quality control, data management, and data reporting.

## **Real-Time Water Quality Monitoring Parameter**

DWR operates sensors along the San Luis Canal that measure salinity and turbidity of water. These continuous measurements are posted on the Internet at:

<http://cdec.water.ca.gov/>

| Site                    | CDEC Code |
|-------------------------|-----------|
| San Luis Canal Check 13 | C13       |
| San Luis Canal Check 21 | C21       |

The values are preliminary and subject to calibration by DWR.

### **Salinity**

Salinity is a measure of dissolved solids in water. It is the sum weight of many different elements within a given volume of water, reported in milligrams per liter (mg/L) or parts per million (ppm). Salinity is an ecological factor of considerable importance, influencing the types of organisms that live in a body of water. Also, salinity influences the kinds of plants and fish that will grow in a water body. Salinity can be estimated by measuring the electrical conductivity (EC) of the water.

### **Turbidity**

Turbidity is the cloudiness or haziness of a fluid caused by large numbers of individual particles that are generally invisible to the naked eye, similar to smoke in air. The measurement of turbidity is a key test of water quality.

Fluids can contain suspended solid matter consisting of particles of many different sizes. While some suspended material will be large enough and heavy enough to settle rapidly to the bottom of the container if a liquid sample is left to stand (the settleable solids), very small particles will settle only very slowly or not at all if the sample is regularly agitated or the particles are colloidal. These small solid particles cause the liquid to appear turbid.

The propensity of particles to scatter a light beam focused on them is now considered a more meaningful measure of turbidity in water. Turbidity measured this way uses an instrument called a nephelometer with the detector set up to the side of the light beam. More light reaches the detector if there are lots of small particles scattering the source beam than if there are few. The units of turbidity from a calibrated nephelometer are called Nephelometric Turbidity Units (NTU). To some extent, how much light reflects for a given amount of particulates is dependent upon properties of the particles like their shape, color, and reflectivity. For this reason (and the reason that heavier particles settle quickly and do not contribute to a turbidity reading), a correlation between turbidity and total suspended solids (TSS) is somewhat unusual for each location or situation.

## **Sampling For Laboratory Analyses of Water Quality**

The following sections describe constituents for laboratory analyses of water quality, as well as methods for water quality sampling and chain of custody documentation.

### **Constituents**

**Table 4** is a short list of constituents to be measured at in each source of non-project water prior to pumping into the San Luis Canal. The costs for collection and lab analyses for the short list tests will be paid the district.

Once the source passes the short list, the operator must have the well tested for the full suite of Title 22 constituents listed in **Table 5**. All water analyses should be conducted by a laboratory that has been audited and approved by Reclamation listed in Table 6. Note all costs to collect and analyze the water for the Title 22 constituents must be paid by the District.

Once the Title 22 standards have been met, then that water may be pumped into the canal, subject to these routine short list tests:

- Weekly, for the first four weeks, to confirm that the water in the well is consistent, predictable, and acceptable
- Monthly, for the duration of pumping, and
- Beginning of each year during the term of the 2015 Warren Act Contract.

Note that the full Title 22 list must be measured every three years.

### **Sampling Methods**

Grab samples will be collected in a bucket or bottle from the point of discharge into the canal. Samples of canal water should be collected mid-stream from a bridge or check structure. Grab samples should be poured directly into sample bottles appropriate to the analyses. The laboratory will specify the sample volume, type of bottle, need for preservative, and special handling requirements for each constituent.

### **Chain of Custody documentation**

Chain of custody (COC) forms will be used to document sample location, collection time, containers, preservation, and analysis. All individuals transferring and receiving samples will sign, date, and record the time on the COC that the samples are transferred. Laboratory COC procedures are described in each laboratory's Quality Assurance Program Manual. Laboratories must receive the COC documentation submitted with each batch of samples and sign, date, and record the time the samples are transferred. Laboratories will also note any sample discrepancies (e.g., labeling, breakage). After generating the laboratory data report for the client, samples will be stored for a minimum

of 30 days in a secured area prior to disposal, or in accordance with the laboratory's protocols for retention of samples.

## **Quality Control**

Quality control (QC) is the overall system of technical activities that measure the attributes and performance of a process, item, or service against defined standards to verify that stated requirements are met.

Quality assurance (QA) is an integrated system of management activities involving, planning, implementation, documentation, assessment, reporting, and quality improvement to ensure that a process, item, or service is of the type and quality needed and expected by the customer. QA objectives will be used to validate the data for this project. The data will be accepted, rejected, or qualified based on how sample results compare to established acceptance criteria.

The precision, accuracy, and contamination criteria will be used by the QCO to validate the data for this project. The criteria will be applied to the blind external duplicate/split, blank, reference, or spiked samples submitted with the production samples to the analytical laboratories by the participating agencies to provide an independent assessment of precision, accuracy, and contamination.

Reclamation may incorporate QC samples into batches of samples to verify the accuracy of the laboratory.

Laboratories analyze their own QC samples with the client's samples. Laboratory QC samples, including laboratory fortified blanks, matrix spikes, duplicates, and method blanks, assess precision, accuracy, and contamination. Laboratory QC criteria are stated in the analytical methods or determined by each laboratory. Since internal control ranges are often updated in laboratories based on instrumentation, personnel, or other influences, it is the responsibility of the QCO to verify that these limits are well documented and appropriately updated during system audits. The preferred method of reporting the QC results is for the laboratory to provide a QC summary report with acceptance criteria for each QC parameter of interest.

For water samples, the QCO will use a statistical program to determine if current concentrations for parameters at given sites are consistent with the historical data at these sites. A result is determined to be a historical outlier if it is greater than 3 standard deviations from the average value for the site. The presence of an outlier could indicate an error in the analytical process or a significant change in the environment. Samples must be prepared, extracted, and analyzed within the recommended holding time for the parameter. Data may be qualified if the sample was analyzed after the holding time expires.

Completeness refers to the percentage of project data that must be successfully collected, validated, and reported to proceed with its intended use in making decisions.

Constraints with regard to time, money, safety, and personnel were some of the factors in choosing the most representative sites for this project. Monitoring sites have been selected by considering the physical, chemical, and biological boundaries that define the system under study.

Sites also were selected to be as representative of the system as possible. However, Reclamation will continue to evaluate the choice of the sites with respect to their representativeness and will make appropriate recommendations to the Contracting Officer given a belief or finding of inadequacy.

Comparability between each agency's data is enhanced through the use of Standard Operating Procedures that detail methods of collection and analysis. Each agency has chosen the best available protocol for the sampling and analyses for which it is responsible based on the agency's own expertise. Audits performed by the QCO will reinforce the methods and practices currently in place and serve to standardize techniques used by the agencies.

### **Data Management**

This program will use data from several independent sources. Each collecting agency will be responsible for its data reduction (analysis), internal data quality control, data storage, and data retrieval.

Real-Time Data – Raw data from field sensors, must be identified as preliminary, subject to change.

Provisional Data - Data that have been reviewed by the collecting agency but may be changed pending re-analyses or statistical review.

Laboratory Data – Data produced by the laboratory following laboratory QA/QC protocols.

### **Data Reporting**

Real-time measurements of salinity and turbidity in the San Luis Canal will be taken by DWR and reported on the California Data Exchange Center. In-stream water quality data will be collected by DWR and Reclamation. Routine measurements of flow from each discharge facility will be taken by District staff, as well as depth of groundwater in each well. All data will be compiled by Reclamation into monthly summary reports that will be shared with DWR, WWD, and the State Water Contractors.

Westlands will issue daily and weekly summaries of the pump-ins.



Westlands and Reclamation will compile salinity data in water balance models to predict the change in salinity in the canal with the addition of groundwater, and compare this with the real-time measurements.

Reclamation and Westlands will compile all flow, water quality, and groundwater data into a final report for future reference.

### **Data Interpretation**

Reclamation and Westlands will share all data for the canal and all wells pumping into the canal with DWR and the State Water Contractors.

Each week, Westlands staff will compile flow measurements. Reclamation will compile real-time salinity and turbidity measurements to determine the changes in the canal. Westlands and Reclamation will use separate mass balances to estimate how much of the observed changes are caused by the conveyance of non-project in the San Luis Canal.

Reclamation will also review monthly water quality reports published by DWR to identify changes and will use the mass balance to determine how the non-project water has affected the canal.

### **Enforcement of Water Quality Standards**

Reclamation will monitor the changes in instream salinity and water quality between Checks 13 and 21 using real-time data and results of monthly grab samples reported by DWR. **Table 3** is a list of the maximum allowable changes in salinity and water quality attributable to the addition of the non-project groundwater.

Reclamation and DWR may conduct field measurements of each discharge to confirm that water quality standards are being met. If any discharge is found not to meet the Title 22 limits, Reclamation will require Westlands to stop the pump-in of non-project water into the Aqueduct.

Reclamation will direct Westlands to stop the pump-in program if, in the judgment of DWR and Reclamation, its continuance could result in disruption of or damage to the SWP, including but not limited to unacceptable degradation of water quality.

Reclamation reserves the right to modify this monitoring program at any time. Additional constituents of concerns may be identified upon review of the well and instream data and be added to the monitoring as determined by DWR and Reclamation.

Revised: 07 July 2017

**Table 1. Real-Time Monitoring Stations**

| Location                                      | Operating Agency | Parameters                         | Frequency | Remarks         |
|---|------------------|------------------------------------|-----------|-----------------|
| San Luis Canal<br>Check 13<br>O'Neill Forebay | DWR              | Electrical conductivity, turbidity | Real-time | CDEC Site: C13  |
| San Luis Canal<br>Check 21<br>Kettleman City  |                  |                                    |           | CDEC site : C21 |

Key: CDEC: California Data Exchange Center

DWR: California Department of Water Resources

**Table 2a. Routine San Luis Canal Water Quality Monitoring Stations**

| Location                                      | Agency | Parameters                                    | Frequency | Remarks     |
|---|--------|---|-----------|-------------|
| San Luis Canal<br>Check 13<br>O'Neill Forebay | DWR    | Minerals, trace metals, nutrients, pesticides | Monthly   | Grab sample |
| San Luis Canal<br>Check 21<br>Kettleman City  |        |   |           | Grab sample |

Source: DWR Water Data Library

**Table 2b. Routine Monitoring of WWD Lateral 7**

| Location  | Agency      | Parameters                | Frequency                        | Remarks                         |
|---|-------------|---------------------------|----------------------------------|---------------------------------|
| San Luis Canal<br>Milepost 113.82<br>Lincoln Ave<br>(upstream site)   | Reclamation | EC, turbidity             | Weekly                           | Field measurements              |
| Westlands Lateral 7<br>at Adams Avenue                                | Reclamation | EC, turbidity, short list | Weekly x 4, Monthly <sup>5</sup> | Field measurements, grab sample |
| San Luis Canal<br>Milepost 117.47<br>Manning Ave<br>(downstream site) | Reclamation | EC, turbidity, selenium   | Weekly                           | Field measurements              |

<sup>5</sup> This water will also be tested for the short list of constituents weekly for the first month and monthly for the duration while water is being pumped into the canal.

**Table 3. Maximum allowable changes in the San Luis Canal caused by the addition of non-project groundwater**

| Constituent                               | Monitoring Location                     | Maximum concentration in the San Luis Canal     |
|---|---|---|
| Daily Change in Electrical conductivity   | Between San Luis Canal Checks 13 and 21 | Less than 100 uS/cm increase between the checks |
| Daily change in turbidity                 |   | Less than 10 NTU                                |
| Concentration of selenium                 | In the San Luis Canal at Check 21       | Not to exceed 2 ug/L                            |
| Concentration of any Title 22 constituent |   | Less than half of a Title 22 MCL                |

If the maximum concentrations are exceeded in the canal, Reclamation will direct the District to reduce or terminate pumping of non-project water into the San Luis Canal. The District may provide a forecast from its water balance model to identify which wells to reduce or terminate, and whether to reduce or terminate pumping from Lateral 7.

**Table 4. Water Quality Standards, Short List**

San Luis Canal  
 Non-Project Water Pump-in Program  
 Water Quality Monitoring Plan

Table 4. Water Quality Standards, Short List

| Constituent            | Units | Maximum Contaminant Level | Detection Limit for Reporting | CAS Registry Number | Recommended Analytical Method |
|------------------------|-------|---------------------------|-------------------------------|---------------------|-------------------------------|
| Arsenic                | mg/L  | 0.01 (1)                  | 0.002 (2)                     | 7440-38-2           | EPA 200.8                     |
| Boron                  | mg/L  | 0.7 (13)                  |                               | 7440-42-8           | EPA 200.7                     |
| Bromide                | mg/L  | (14)                      |                               |                     |                               |
| Chloride               | mg/L  | 250 (7)                   |                               | 16887-00-6          | EPA 300.1                     |
| Chromium, total        | mg/L  | 0.005 (1)                 | 0.001 (2)                     | 7440-47-3           | EPA 200.7                     |
| Hexavalent chromium    | mg/L  | 0.010 (1)                 | 0.0004 (2)                    | 18540-29-9          | EPA 200.8                     |
| Manganese              | mg/L  | 0.05 (1)                  |                               | 7439-96-5           | EPA 200.7                     |
| Nitrate (as nitrogen)  | mg/L  | 10 (1)                    | 0.4 (2)                       | 7727-37-9           | EPA 300.1                     |
| Selenium               | mg/L  | 0.002 (10)                | 0.0004 (2)                    | 7782-49-2           | EPA 200.8                     |
| Sodium                 | mg/L  | 69 (12)                   |                               | 7440-23-5           | EPA 200.7                     |
| Specific Conductance   | µS/cm | 1,600 (7)                 |                               |                     | SM 2510B                      |
| Sulfate                | mg/L  | 500 (7)                   |                               | 14808-79-8          | EPA 300.1                     |
| Total Dissolved Solids | mg/L  | 1,000 (7)                 |                               |                     | SM 2540C                      |
| Total Organic Carbon   | mg/L  | (14)                      |                               |                     | EPA 415.3                     |
| Gross alpha (*)        | pCi/L | 15 (3)                    | 3 (3)                         |                     | SM 7110C                      |

Short list to be measured before pumping occurs, then weekly for four consecutive weeks, and monthly for the duration of pumping into the San Luis Canal.

(\*) Monthly testing only

Revised: 27 July 2017

**Table 5. Water Quality Standards, Full Title 22 Analysis**

San Luis Canal

Non-Project Water Pump-in Program  
2017 Water Quality Monitoring Plan

Table 5. Title 22 Water Quality Standards

| Constituent                         | Units | Maximum Contaminant Level | Detection Limit for Reporting | CAS Registry Number | Recommended Analytical Method |
|-------------------------------------|-------|---------------------------|-------------------------------|---------------------|-------------------------------|
| <b>Primary</b>                      |       |                           |                               |                     |                               |
| Aluminum                            | mg/L  | 1 (1)                     | 0.05 (2)                      | 7429-90-5           | EPA 200.7                     |
| Antimony                            | mg/L  | 0.006 (1)                 | 0.006 (2)                     | 7440-36-0           | EPA 200.8                     |
| Arsenic                             | mg/L  | 0.01 (1)                  | 0.002 (2)                     | 7440-38-2           | EPA 200.8                     |
| Asbestos                            | MFL   | 7 (1)                     | 0.2 MFL>10um (2)              | 1332-21-4           | EPA 100.2                     |
| Barium                              | mg/L  | 1 (1)                     | 0.1 (2)                       | 7440-39-3           | EPA 200.7                     |
| Beryllium                           | mg/L  | 0.004 (1)                 | 0.001 (2)                     | 7440-41-7           | EPA 200.7                     |
| Cadmium                             | mg/L  | 0.005 (1)                 | 0.001 (2)                     | 7440-43-9           | EPA 200.7                     |
| Chromium, total                     | mg/L  | 0.05 (1)                  | 0.01 (2)                      | 7440-47-3           | EPA 200.7                     |
| Copper                              | mg/L  | 1.3                       |                               | 7440-50-8           | EPA 200.7                     |
| Cyanide                             | mg/L  | 0.15 (1)                  | 0.1 (2)                       | 57-12-5             | EPA 335.2                     |
| Fluoride                            | mg/L  | 2.0 (1)                   | 0.1 (2)                       | 16984-48-8          | EPA 300.1                     |
| Hexavalent Chromium                 | mg/L  | 0.010 (1)                 | 0.001 (2)                     | 18540-29-9          | EPA 218.7                     |
| Lead                                | mg/L  | 0.015 (9)                 | 0.005 (8)                     | 7439-92-1           | EPA 200.8                     |
| Mercury                             | mg/L  | 0.002 (1)                 | 0.001 (2)                     | 7439-97-6           | EPA 245.1                     |
| Nickel                              | mg/L  | 0.1 (1)                   | 0.01 (2)                      | 7440-02-0           | EPA 200.7                     |
| Nitrate (as nitrogen)               | mg/L  | 10 (1)                    | 0.4 (2)                       | 7727-37-9           | EPA 300.1                     |
| Nitrate + Nitrite (sum as nitrogen) | mg/L  | 10 (1)                    |                               | 14797-55-8          | EPA 353.2                     |

|                       |      |            |            |            |                 |
|-----------------------|------|------------|------------|------------|-----------------|
| Nitrite (as nitrogen) | mg/L | 1 (1)      | 0.4 (2)    | 14797-65-0 | EPA 300.1       |
| Perchlorate           | mg/L | 0.006 (1)  | 0.004 (2)  | 14797-73-0 | EPA 314/331/332 |
| Selenium              | mg/L | 0.002 (10) | 0.0004 (2) | 7782-49-2  | EPA 200.8       |
| Thallium              | mg/L | 0.002 (1)  | 0.001 (2)  | 7440-28-0  | EPA 200.8       |
| Thiobencarb           | mg/L | 0.07       |            | 28249-77-6 | EPA 527         |

### Secondary

|                                |       |           |          |            |                   |
|--------------------------------|-------|-----------|----------|------------|-------------------|
| Aluminum                       | mg/L  | 200 (6)   |          | 7429-90-5  | EPA 200.7         |
| Chloride                       | mg/L  | 500 (7)   |          | 16887-00-6 | EPA 300.1         |
| Color                          | units | 15 (6)    |          |            | EPA 110           |
| Copper                         | mg/L  | 1 (6)     | 0.05 (8) | 7440-50-8  | EPA 200.7         |
| Iron                           | mg/L  | 0.3 (6)   |          | 7439-89-6  | EPA 200.7         |
| Manganese                      | mg/L  | 0.05 (6)  |          | 7439-96-5  | EPA 200.7         |
| Methyl-tert-butyl ether (MTBE) | mg/L  | 0.013 (4) |          | 1634-04-4  | EPA 502.2/524.2   |
| Odor -threshold                | units | 3 (6)     |          |            | SM 2150B          |
| Silver                         | mg/L  | 0.1 (6)   |          | 7440-22-4  | EPA 200.7         |
| Specific Conductance           | µS/cm | 1,600 (7) |          |            | SM 2510 B         |
| Sulfate                        | mg/L  | 500 (7)   |          | 14808-79-8 | EPA 300.1         |
| Thiobencarb                    | mg/L  | 0.001 (6) |          | 28249-77-6 | EPA 527           |
| Total Dissolved Solids         | mg/L  | 1,000 (7) |          |            | SM 2540 C         |
| Turbidity                      | units | 5 (6)     |          |            | EPA 190.1/SM2130B |
| Zinc                           | mg/L  | 5 (6)     |          | 7440-66-6  | EPA 200.7         |

### Other Required Analyses

|            |      |           |  |           |           |
|------------|------|-----------|--|-----------|-----------|
| Boron      | mg/L | 0.7 (13)  |  | 7440-42-8 | EPA 200.7 |
| Molybdenum | mg/L | 0.01 (11) |  | 7439-98-7 | EPA 200.7 |
| Sodium     | mg/L | 69 (12)   |  | 7440-23-5 | EPA 200.7 |



**Radioactivity**

|             |       |        |       |          |
|-------------|-------|--------|-------|----------|
| Gross Alpha | pCi/L | 15 (3) | 3 (3) | SM 7110C |
|-------------|-------|--------|-------|----------|

**Organic Chemicals**

## (a) Volatile Organic Chemicals (VOCs)

|                            |      |            |            |           |                 |
|----------------------------|------|------------|------------|-----------|-----------------|
| Benzene                    | mg/L | 0.001 (4)  | 0.0005 (5) | 71-43-2   | EPA 502.2/524.2 |
| Carbon Tetrachloride       | mg/L | 0.0005 (4) | 0.0005 (5) | 56-23-5   | EPA 502.2/524.2 |
| 1,2-Dichlorobenzene.       | mg/L | 0.6 (4)    | 0.0005 (5) | 95-50-1   | EPA 502.2/524.2 |
| 1,4-Dichlorobenzene.       | mg/L | 0.005 (4)  | 0.0005 (5) | 106-46-7  | EPA 502.2/524.2 |
| 1,1-Dichloroethane         | mg/L | 0.005 (4)  | 0.0005 (5) | 75-34-3   | EPA 502.2/524.2 |
| 1,2-Dichloroethane         | mg/L | 0.0005 (4) | 0.0005 (5) | 107-06-2  | EPA 502.2/524.2 |
| 1,1-Dichloroethylene       | mg/L | 0.006 (4)  | 0.0005 (5) | 75-35-4   | EPA 502.2/524.2 |
| cis-1,2-Dichloroethylene   | mg/L | 0.006 (4)  | 0.0005 (5) | 156-59-2  | EPA 502.2/524.2 |
| trans-1,2-Dichloroethylene | mg/L | 0.01 (4)   | 0.0005 (5) | 156-60-5  | EPA 502.2/524.2 |
| Dichloromethane.           | mg/L | 0.005 (4)  | 0.0005 (5) | 75-09-2   | EPA 502.2/524.2 |
| 1,2-Dichloropropane.       | mg/L | 0.005 (4)  | 0.0005 (5) | 78-87-5   | EPA 502.2/524.2 |
| 1,3-Dichloropropene.       | mg/L | 0.0005 (4) | 0.0005 (5) | 542-75-6  | EPA 502.2/524.2 |
| Ethylbenzene.              | mg/L | 0.3 (4)    | 0.0005 (5) | 100-41-4  | EPA 502.2/524.2 |
| Methyl-tert-butyl ether    | mg/L | 0.013 (4)  | 0.003 (5)  | 1634-04-4 | EPA 502.2/524.2 |
| Monochlorobenzene          | mg/L | 0.07 (4)   | 0.0005 (5) | 108-90-7  | EPA 502.2/524.2 |
| Styrene.                   | mg/L | 0.1 (4)    | 0.0005 (5) | 100-42-5  | EPA 502.2/524.2 |
| 1,1,2,2-Tetrachloroethane. | mg/L | 0.001 (4)  | 0.0005 (5) | 79-34-5   | EPA 502.2/524.2 |
| Tetrachloroethylene (PCE)  | mg/L | 0.005 (4)  | 0.0005 (5) | 127-18-4  | EPA 502.2/524.2 |
| Toluene                    | mg/L | 0.15 (4)   | 0.0005 (5) | 108-88-3  | EPA 502.2/524.2 |
| 1,2,4-Trichlorobenzene     | mg/L | 0.005 (4)  | 0.0005 (5) | 120-82-1  | EPA 502.2/524.2 |
| 1,1,1-Trichloroethane      | mg/L | 0.2 (4)    | 0.0005 (5) | 71-55-6   | EPA 502.2/524.2 |
| 1,1,2-Trichloroethane      | mg/L | 0.005 (4)  | 0.0005 (5) | 79-00-5   | EPA 502.2/524.2 |
| Trichloroethylene (TCE)    | mg/L | 0.005 (4)  | 0.0005 (5) | 79-01-6   | EPA 502.2/524.2 |
| Trichlorofluoromethane     | mg/L | 0.15 (4)   | 0.005 (5)  | 75-69-4   | EPA 502.2/524.2 |

|   |      |         |     |         |     |            |                 |
|---|------|---------|-----|---------|-----|------------|-----------------|
| 1,1,2-Trichloro-1,2,2-Trifluoroethane.              | mg/L | 1.2     | (4) | 0.01    | (5) | 76-13-1    | SM 6200B        |
| Vinyl Chloride                                      | mg/L | 0.0005  | (4) | 0.0005  | (5) | 75-01-4    | EPA 502.2/524.2 |
| Xylenes   | mg/L | 1.750*  | (4) | 0.0005  | (5) | 1330-20-7  | EPA 502.2/524.2 |
| (b) Non-Volatile Synthetic Organic Chemicals (SOCs) |      |         |     |         |     |            |                 |
| Alachlor  | mg/L | 0.002   | (4) | 0.001   | (5) | 15972-60-8 | EPA 505/507/508 |
| Atrazine  | mg/L | 0.001   | (4) | 0.0005  | (5) | 1912-24-9  | EPA 505/507/508 |
| Bentazon  | mg/L | 0.018   | (4) | 0.002   | (5) | 25057-89-0 | EPA 515.1       |
| Benzo(a)pyrene                                      | mg/L | 0.0002  | (4) | 0.0001  | (5) | 50-32-8    | EPA 525.2       |
| Carbofuran  | mg/L | 0.018   | (4) | 0.005   | (5) | 1563-66-2  | EPA 531.1       |
| Chlordane   | mg/L | 0.0001  | (4) | 0.0001  | (5) | 57-74-9    | EPA 505/508     |
| 2,4-D   | mg/L | 0.07    | (4) | 0.01    | (5) | 94-75-7    | EPA 515.1       |
| Dalapon   | mg/L | 0.2     | (4) | 0.01    | (5) | 75-99-0    | EPA 515.1       |
| Dibromochloropropane                                | mg/L | 0.0002  | (4) | 0.00001 | (5) | 96-12-8    | EPA 502.2/504.1 |
| Di(2-ethylhexyl)adipate                             | mg/L | 0.4     | (4) | 0.005   | (5) | 103-23-1   | EPA 506         |
| Di(2-ethylhexyl)phthalate                           | mg/L | 0.004   | (4) | 0.003   | (5) | 117-81-7   | EPA 506         |
| Dinoseb   | mg/L | 0.007   | (4) | 0.002   | (5) | 88-85-7    | EPA 5151-4      |
| Diquat  | mg/L | 0.02    | (4) | 0.004   | (5) | 85-00-7    | EPA 549.2       |
| Endothall   | mg/L | 0.1     | (4) | 0.045   | (5) | 145-73-3   | EPA 548.1       |
| Endrin.   | mg/L | 0.002   | (4) | 0.0001  | (5) | 72-20-8    | EPA 505/508     |
| Ethylene Dibromide                                  | mg/L | 0.00005 | (4) | 0.00002 | (5) | 106-93-4   | EPA 502.2/504.1 |
| Glyphosate (Roundup)                                | mg/L | 0.7     | (4) | 0.025   | (5) | 1071-83-6  | EPA 547         |
| Heptachlor.   | mg/L | 0.00001 | (4) | 0.00001 | (5) | 76-44-8    | EPA 508         |
| Heptachlor Epoxide                                  | mg/L | 0.00001 | (4) | 0.00001 | (5) | 1024-57-3  | EPA 508         |
| Hexachlorobenzene                                   | mg/L | 0.001   | (4) | 0.0005  | (5) | 118-74-1   | EPA 505/508     |
| Hexachlorocyclopentadiene                           | mg/L | 0.05    | (4) | 0.001   | (5) | 77-47-4    | EPA 505/508     |
| Lindane (gamma-BHC)                                 | mg/L | 0.0002  | (4) | 0.0002  | (5) | 58-89-9    | EPA 505/508     |
| Methoxychlor  | mg/L | 0.03    | (4) | 0.01    | (5) | 72-43-5    | EPA 505/508     |
| Molinate  | mg/L | 0.02    | (4) | 0.002   | (5) | 2212-67-1  | EPA 525.1       |
| Oxamyl  | mg/L | 0.05    | (4) | 0.02    | (5) | 23135-22-0 | EPA 531.1       |
| Pentachlorophenol                                   | mg/L | 0.001   | (4) | 0.0001  | (5) | 87-86-5    | EPA 515.1-3     |

|                           |      |                      |      |                      |     |            |             |
|---------------------------|------|----------------------|------|----------------------|-----|------------|-------------|
| Picloram                  | mg/L | 0.5                  | (4)  | 0.001                | (5) | 1918-02-1  | EPA 515.1-3 |
| Polychlorinated Biphenyls | mg/L | 0.0005               | (4)  | 0.0005               | (5) | 1336-36-3  | EPA 130.1   |
| Simazine                  | mg/L | 0.004                | (4)  | 0.001                | (5) | 122-34-9   | EPA 505     |
| Thiobencarb (Bolero)      | mg/L | 0.07                 | (4)  | 0.001                | (5) | 28249-77-6 | EPA 527     |
| Toxaphene                 | mg/L | 0.003                | (4)  | 0.001                | (5) | 8001-35-2  | EPA 505     |
| 2,3,7,8-TCDD (Dioxin)     | mg/L | 3 x 10 <sup>-8</sup> | (4)  | 5 x 10 <sup>-9</sup> | (5) | 1746-01-6  | EPA 130.3   |
| 2,4,5-TP (Silvex)         | mg/L | 0.05                 | (4)  | 0.001                | (5) | 93-72-1    | EPA 515.1   |
| Other Organic Chemicals   |      |                      |      |                      |     |            |             |
| Chlorpyrifos              | ug/L | 0.015                | (11) |                      |     | 2921-88-2  | EPA 8141A   |
| Diazinon                  | ug/L | 0.10                 | (11) |                      |     | 333-41-5   | EPA 8141A   |

---

Sources:

Recommended Analytical Methods: <https://www.nemi.gov/home/>

Maximum Contaminant Levels:

Title 22. The Domestic Water Quality and Monitoring Regulations specified by the State of California Health and Safety Code (Sections 4010-4037), and Administrative Code (Sections 64401 et seq.), as amended.

- (1) Title 22. Table 64431-A Maximum Contaminant Levels, Inorganic Chemicals
- (2) Title 22. Table 64432-A Detection Limits for Reporting (DLRs) for Regulated Inorganic Chemicals
- (3) Title 22. Table 64442 Radionuclide Maximum Contaminant Levels (MCLs) and Detection Levels for Purposes of Reporting (DLRs)
- (4) Title 22. Table 64444-A Maximum Contaminant Levels, Organic Chemicals
- (5) Title 22. Table 64445.1-A Detection Limits for Purposes of Reporting (DLRs) for Regulated Organic Chemicals
- (6) Title 22. Table 64449-A Secondary Maximum Contaminant Levels "Consumer Acceptance Contaminant Levels"
- (7) Title 22. Table 64449-B Secondary Maximum Contaminant Levels "Consumer Acceptance Contaminant Level Ranges"
- (8) Title 22. Table 64678-A DLRs for Lead and Copper
- (9) Title 22. Section 64678 (d) Lead Action level

[http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/documents/lawbook/dwregulations-2015-07-16.pdf](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/documents/lawbook/dwregulations-2015-07-16.pdf)

California Regional Water Quality Control Board, Central Valley Region, Fourth Edition of the Water Quality Control Plan for the Sacramento River and San Joaquin River Basins. Revised June 2015

(10) Basin Plan, Table III-1 (ug/L) (selenium in Grasslands water supply channels)

(11) Basin Plan, Table III-2A. 4-day average (chronic) concentrations of chlorpyrifos & diazinon in San Joaquin River from Mendota to Vernalis

[http://www.waterboards.ca.gov/centralvalley/water\\_issues/basin\\_plans/sacsjr.pdf](http://www.waterboards.ca.gov/centralvalley/water_issues/basin_plans/sacsjr.pdf)

Ayers, R. S. and D. W. Westcot, *Water Quality for Agriculture*, Food and Agriculture Organization of the United Nations - Irrigation and Drainage Paper No. 29, Rev. 1, Rome (1985).

(12) Ayers, Table 1 (mg/L) (sodium)

(13) Ayers, Table 21 (mg/L) (boron)

<http://www.fao.org/DOCREP/003/T0234E/T0234E00.HTM>

(14) Requested by State Water contractors, no MCL specified.

revised: 27 July 2017

**Table 6. List of Reclamation Approved Laboratories**



# RECLAMATION

*Managing Water in the West*

**Table 6. Approved Laboratory List for the Mid-Pacific Region  
Quality Assurance and Data Management Branch (MP-156)  
Environmental Monitoring and Hazardous Materials Branch (MP-157)**

|  |                       |  |
|--|-----------------------|--|
| Alpha Analytical<br>Laboratories, Inc. | <b><u>Address</u></b> | 208 Mason Street, Ukiah, CA 95482                                      |
|  | <b><u>Contact</u></b> | Adam Angulo  |
|  | <b><u>P/F</u></b>     | 916-686-5190   |
|  | <b><u>Email</u></b>   | adam@alpha-labs.com  |
|  | <b><u>Methods</u></b> | <i>Inorganics in Water, Organics in Water</i>                          |
| APPL Laboratory                        | <b><u>Address</u></b> | 908 North Temperance Avenue, Clovis, CA 93611                          |
|  | <b><u>Contact</u></b> | Renee' Patterson, Project Manager                                      |
|  | <b><u>P/F</u></b>     | (559) 275-2175 / (559) 275-4422  |
|  | <b><u>Email</u></b>   | rpatterson@applinc.com; danderson@applinc.com;                         |
|  | <b><u>Methods</u></b> | <i>Approved for inorganic and organic parameters in water and soil</i> |

|                         |                       |  |
|-------------------------|-----------------------|--|
| <b>Basic Laboratory</b> | <b><u>Address</u></b> | 2218 Railroad Avenue Redding, CA 96001   |
|                         | <b><u>Contact</u></b> | Josh Kirkpatrick, Nathan Hawley, Melissa Hawley  |
|                         | <b><u>P/F</u></b>     | (530) 243-7234 / (530) 243-7494  |
|                         | <b><u>Email</u></b>   | jkirkpatrick@basiclab.com (QAO and PM); nhawley@basiclab.com, mhawley@basiclab.com (invoices); poilar@basiclab.com (sample custody), khawley@basiclab.com (sample custody) |
|                         | <b><u>Methods</u></b> | <i>Approved for inorganic/organic parameters</i>   |

|                            |                       |   |
|----------------------------|-----------------------|---|
| <b>Brooks Applied Labs</b> | <b><u>Address</u></b> | 18804 North Creek Parkway Bothell, WA 98011   |
|                            | <b><u>Contact</u></b> | Jeremy Maute  |
|                            | <b><u>P/F</u></b>     | (206) 632-6206  |
|                            | <b><u>Email</u></b>   | <a href="mailto:Jeremy@brooksapplied.com">Jeremy@brooksapplied.com</a>                      |
|                            | <b><u>Methods</u></b> | <i>Approved for selenium speciation and mercury speciation in water, solids, and tissue</i> |

|                                       |                       |  |
|---------------------------------------|-----------------------|--|
| <b>California Laboratory Services</b> | <b><u>Address</u></b> | 3249 Fitzgerald Road Rancho Cordova, CA 95742                          |
|                                       | <b><u>Contact</u></b> | Scott Furnas   |
|                                       | <b><u>P/F</u></b>     | (916) 638-7301 / (916) 638-4510  |
|                                       | <b><u>Email</u></b>   | janetm@californialab.com (QA); scottf@californialab.com (PM)           |
|                                       | <b><u>Methods</u></b> | <i>Approved for inorganic, organic, and microbiological parameters</i> |



Calscience  
Environmental  
Laboratories

|                       |  |
|-----------------------|--|
| <b><u>Address</u></b> | 7440 Lincoln Way; Garden Grove, CA 92841   |
| <b><u>Contact</u></b> | Don Burley   |
| <b><u>P/F</u></b>     | 714-895-5494 (ext. 203)/714-894-7501   |
| <b><u>Email</u></b>   | DBurley@calscience.com   |
| <b><u>Methods</u></b> | <i>Approved for inorganic and organic parameters in water, sediment, and soil.</i> |

Eurofins Eaton  
Analytical, Inc.  
(formerly MWH  
Laboratories)

|                       |   |
|-----------------------|---|
| <b><u>Address</u></b> | 750 Royal Oaks Drive Ste. 100 Monrovia, CA 91016 USA  |
| <b><u>Contact</u></b> | Linda Geddes  |
| <b><u>P/F</u></b>     | (626) 386-1100, Linda - (626) 386-1163, Rick - (626) 386-1157   |
| <b><u>Email</u></b>   | LindaGeddes@eurofinsus.com  |
| <b><u>Methods</u></b> | <i>Approved for all inorganic, organic, radiochemistry, total coliform, &amp; E. Coli parameters in water</i> |

Fruit Growers  
Laboratory

|                       |  |
|-----------------------|--|
| <b><u>Address</u></b> | 853 Corporation Street Santa Paula, CA 93060 USA                           |
| <b><u>Contact</u></b> | David Terz, QA Director  |
| <b><u>P/F</u></b>     | (805) 392-2024 / (805) 525-4172  |
| <b><u>Email</u></b>   | <a href="mailto:davidt@fglinc.com">davidt@fglinc.com</a>                   |
| <b><u>Methods</u></b> | <i>Approved for the analysis of inorganic parameters in water and soil</i> |

Moore Twining  
Associates, Inc.

|                       |  |
|-----------------------|--|
| <b><u>Address</u></b> | 2527 Fresno St., Fresno, CA 93721 USA                |
| <b><u>Contact</u></b> | Juli Adams (Lab Director), Maria Manuel (QA Manager) |
| <b><u>P/F</u></b>     | (559) 268-7021                                       |
| <b><u>Email</u></b>   | julia@mooretwining.com, mariam@mooretwining.com      |
| <b><u>Methods</u></b> | <i>BOD</i>   |

**Oilfield  
Environmental &  
Compliance**

|                       |   |
|-----------------------|---|
| <b><u>Address</u></b> | 307 Roemer Way Ste 300, Santa Maria, CA 93454           |
| <b><u>Contact</u></b> | Will update when assigned a PM                          |
| <b><u>P/F</u></b>     | 805-922-4772  |
| <b><u>Email</u></b>   | info@oecusa.com   |
| <b><u>Methods</u></b> | <i>(Approval Pending) Hazardous Waste in Water/Soil</i> |

**Pacific EcoRisk**

|                       |   |
|-----------------------|---|
| <b><u>Address</u></b> | 2250 Codelia Road, Fairfield, CA 94534 USA      |
| <b><u>Contact</u></b> | Stephen L. Clark                                |
| <b><u>P/F</u></b>     | (707) 207-7760 / (707) 207-7916                 |
| <b><u>Email</u></b>   | slclark@pacificecorisk.com                      |
| <b><u>Methods</u></b> | <i>Approved for acute and chronic toxicity.</i> |

**Physis**

|                       |  |
|-----------------------|--|
| <b><u>Address</u></b> | 1904 East Wright Circle, Anaheim, CA 92806   |
| <b><u>Contact</u></b> | Will update when assigned a PM               |
| <b><u>P/F</u></b>     | 1-714-602-5320 ext 204                       |
| <b><u>Email</u></b>   | markbaker@physislabs.com                     |
| <b><u>Methods</u></b> | <i>(Approval Pending) Inorganics in Soil</i> |

**South Dakota  
Agricultural  
Laboratories**

|                       |   |
|-----------------------|---|
| <b><u>Address</u></b> | Brookings Biospace, 1006 32nd Avenue, Suites 103,105, Brookings, SD 57006-4728        |
| <b><u>Contact</u></b> | Regina Wixon, Nancy Anderson, Jessie Davis (sample custodian)                         |
| <b><u>P/F</u></b>     | (605) 692-7325/(605) 692-7326   |
| <b><u>Email</u></b>   | regina.wixon@sdaglabs.com, Nancy.Anderson@sdaglabs.com,<br>jessica.davis@sdaglabs.com |
| <b><u>Methods</u></b> | <i>Approved for selenium analysis</i>   |

Western  
Environmental  
Testing  
Laboratories

|                       |   |
|-----------------------|---|
| <b><u>Address</u></b> | 475 East Greg Street # 119 Sparks, NV 89431 USA                                     |
| <b><u>Contact</u></b> | Scott Thompson (Client Services), Andy Smith (Lab Drctr)                            |
| <b><u>P/F</u></b>     | (775) 355-0202 / (775) 355-0817   |
| <b><u>Email</u></b>   | scottt@wetlaboratory.com, andy@wetlaboratory.com                                    |
| <b><u>Methods</u></b> | <i>Approved for inorganic parameters (metals, general chemistry) and coliforms.</i> |

Revised: 08 February 2017

**Appendix A. Department of Water Resources Water Quality Policy and Implementation Process for Acceptance of Non-Project Water into the State Water Project (October 2012)**

# **Department of Water Resources Water Quality Policy and Implementation Process for Acceptance of Non-Project Water into the State Water Project (October 2012)**

It is the Department of Water Resources (DWR) policy to assist with the conveyance of water to provide water supply, and to protect the State Water Project (SWP) water quality within the California Aqueduct. To facilitate this policy DWR provides the following implementation process for accepting non-project water into the SWP (Policy). For purposes of this document, SWP and California Aqueduct are interchangeable and the same.

## **POLICY PROVISIONS**

DWR shall consider and evaluate all requests for Non-Project (NP) water input directly into the SWP conveyance facilities based upon the criteria established in this document. NP water shall be considered to be any water input into the SWP for conveyance by the SWP that is not directly diverted from the Sacramento-San Joaquin Delta or natural inflow into SWP reservoirs.

The proponent of any NP water input proposal shall demonstrate that the water is of consistent, predictable, and acceptable quality.

DWR will consult with State Water Project (Contractors), existing NP participants and the Department of Public Health (DPH) on drinking water quality issues relating to NP water as needed to assure the protection of SWP water quality.

Nothing in this document shall be construed as authorizing the objectives of Article 19 of the SWP water supply contracts or DPH drinking water maximum contaminant levels to be exceeded.

This Policy shall not constrain the ability of DWR to operate the SWP for its intended purposes and shall not adversely impact SWP water deliveries, operation or facilities.

## **EVALUATING NP WATER PROPOSALS**

DWR shall use a two-tiered approach for evaluating NP water for input into the California Aqueduct.

### **NP Tier 1**

Tier 1 NP pump-in proposals (PIP) shall exhibit water quality that is essentially the same, or better, than what occurs in the California Aqueduct. PIP's considered to be tier 1 shall be approved by DWR (see baseline water quality tables 1 through 4).

## **NP Tier 2**

Tier 2 PIP's are those that exhibit water quality that is different and possibly worse than in the California Aqueduct and/or have the potential to cause adverse impacts to the Contractors. Tier 2 PIP's shall be referred to a NP Facilitation Group (FG), which would review the project and if needed make recommendations to DWR in consideration of the PIP.

### **SWC Facilitation Group**

This advisory group consists of representatives from each Contractor that chooses to participate and DWR. The group shall review tier 2 PIP's based on the merits, impacts, mitigation, water quality monitoring, cost/benefits or other issues of each PIP and provide recommendations to DWR. Upon initial review of tier 2 PIP by DWR, it shall then be submitted to the FG for review. A consensus recommendation from the FG would be sought regarding approval of the PIP. DWR shall base its decision on the merits of the PIP, recommendations of the FG and the PIP's ability to provide overall benefits to the SWP and the State of California.

### **Blending Water Sources**

Blending of multiple water sources prior to inflow into the SWP is acceptable and may be preferred depending upon water quality of the PIP. Blending of water in this manner may be used to qualify a project as NP Tier 1.

Mixing (blending) within the California aqueduct can be considered but shall not be adjacent to municipal and industrial (M&I) delivery locations. PIP's that are coordinating water discharged to maintain or improve SWP water quality are an example of the mixing approach. The PIP shall demonstrate by model or an approach acceptable to DWR and the FG that the water is adequately mixed before reaching the first M&I customer. Generally NP PIP's that involve mixing with SWP water shall be considered NP Tier 2.

### **Baseline Water Quality**

To aid in developing and evaluating PIP's both historical and current SWP water quality levels shall be considered. A representative baseline water quality summary is shown in Tables 1 through 4, using historical SWP water quality records at O'Neill Forebay.

## **NP IMPLEMENTATION PROCESS**

### **Project Proposals**

The NP project proponent requesting to introduce water into the SWP shall submit a detailed PIP to DWR. The proponent shall demonstrate that the NP water is of consistent, predictable and reliable quality, and is responsible for preparing and complying with any and all contracts, environmental documents, permits or licenses that are necessary consistent with applicable laws, regulations, agreements, procedures, or policies.

### **Project Description**

The proponent will submit to DWR a PIP describing the proposed program, identifying the water source(s), planned operation, characterizing the inflow water quality and any anticipated impacts to SWP water quality and/or operations. The PIP should be submitted at least one month prior to proposed start up to allow for DWR and FG review. The PIP shall include:

- Project proponent names, locations, addresses, and contact person(s).
- Maps identifying all sources of water, point of inflow to the SWP and ultimate fate of the introduced water.
- Terms and conditions of inflow, timing, rates and volumes of inflow, pumping, conveyance and storage requirements.
- Construction details of any facilities located adjacent to the SWP including valves, meters, and pump and piping size.
- All potential impacts and/or benefits to downstream SWP water contractors.
- Detailed water quality data for all sources of water and any blend of sources that will be introduced into the SWP.
- Identify anticipated water quality changes within the SWP.
- Identify other relevant environmental issues such as subsidence, ground water overdraft or, presents of endangered species.
- Provide performance measures and remedial actions that will be taken in the event projected SWP water quality levels are not met.
- Reference an existing contract or indicate that one is in process with DWR to conduct a PIP.

### **Water Quality Monitoring**

In order to demonstrate that the water source(s) are of consistent, predictable, and acceptable quality the NP proponent shall monitor water quality. The proponent shall, for the duration of the program, regularly report on operations as they affect water quality, monitoring data and water quality changes. Both DPH title 22 and a short list of Constituents of Concern (COC) shall be monitored for based upon one of the following water quality monitoring options.

Constituents of Concern Current COC are Arsenic, Bromide, Chloride, Nitrate, Sulfate, Organic Carbon, and Total Dissolved Solids. These COC's may be changed as needed.

Water Quality Monitoring Options NP proponents shall select one of the testing options below and perform all water quality testing and provide analytical results in a timely manner as described herein. Monitoring shall be conducted for initial well start-up, periodic well re-testing and on-going testing during operation. Well data should be no more than three years old. Title 22 results should be provided to DWR and the FG within two weeks of testing and COC results within one week of testing, unless other schedules are agreed upon by DWR and the FG.

### ***Option 1 - Baseline tests for Individual Wells***

Well Start-up: Title 22 tests are required for all wells participating in the program prior to start-up. An existing title 22 test that is no more than three years old may be used. A Title 22 test may be substituted for any well near a similar well with a Title 22 test of record.

Well Re-testing: Title 22 test for all wells participating every three years.

Ongoing Monitoring: COC tests are required for all discharge locations to the SWP at start up and quarterly thereafter for new programs and resumption of established programs. New programs or those with constituents that may potentially degrade the SWP shall conduct at least weekly COC sampling of all discharge locations until the proponent demonstrates that the NP water is of consistent, predictable and reliable quality. Once the nature of the discharge has been clearly established, the COC tests are required quarterly for each discharge point.

### ***Option 2 - Baseline tests for Representative Wells***

Well Start-up: COC tests of record are required for all wells participating in the program and Title 22 tests of record are required for representative wells comprising a subset of all wells. This would typically be a group of wells that are manifold together and discharge to one pipe. Representative wells shall be identified on a case-by-case basis to be representative of the manifold area, well proximity, and water levels.

Well Re-testing: Same as required in Option 1.

On-going Monitoring: COC tests are required for all discharge locations to the SWP at start up and monthly thereafter for the duration of the program and annually at each well. New programs or those with constituents that may potentially degrade the SWP shall conduct weekly COC sampling of all discharge locations until the proponent demonstrates that the NP water is of consistent, predictable and reliable quality.

### ***Option 3 – Self Directed***

A PIP may propose a water quality monitoring program for approval by DWR and the FG that is different from options 1 or 2. It must include COC and title 22 testing that will



fully characterize water pumped into the SWP and be at an interval to show a consistent, predictable and reliable quality.

### **Analytical Methods**

Analytical laboratories used by project proponents shall be DPH certified by the Environmental Laboratory Accreditation Program (ELAP) and use EPA prescribed and ELAP accredited methods for drinking water analysis. Minimum Reporting Levels must be at least as low as the DPH required detection limits for purposes of reporting (DLR). The current DLRs are listed on the DPH website at [Http://www.cdph.ca.gov/certlic/drinkingwater/Pages/MCLsandPHGs](http://www.cdph.ca.gov/certlic/drinkingwater/Pages/MCLsandPHGs). DWR shall continue to use Bryte Chemical Laboratory as it's analytical and reference lab.

### **Flow Measurements**

The project proponent shall maintain current, accurate records of water production rate and volume from each source, as well as, each point of discharge into the SWP. All flow measurements shall be submitted to regularly to DWR.

### **RECONSIDERATION**

If an NP proponent disagrees with the FG or DWR decision or feels that there is an overriding benefit of the proposal, the proponent may request reconsideration from DWR on the basis of overriding public benefit or water supply deficiency. DWR shall consider these requests on a case-by-case basis.

### **ONGOING PROGRAM**

Any NP Proponent who has successfully established a NP water inflow program (Including existing Kern Fan Banking Projects, Kern Water Bank, Pioneer and Berrenda Mesa Projects, Semitropic Water Storage District Wheeler Ridge Mariposa Water Storage District and Arvin Edison Water Storage District) may reinstate the program by notifying DWR at least ten days before inflow is scheduled to begin and provide the following information:

- Updated water quality data and/or updated modeling that adequately reflects the quality of water to be introduced into the SWP.
- Turn-in location.
- Expected rate and duration of inflow. DWR shall notify the FG of this reinstating of inflow.
- Water quality monitoring schedule that meets the objective of this policy.

### **FUTURE NP PROGRAMS**

Future NP projects should be planned and designed considering the following items:

- Projects involving water quality exceeding primary drinking water standards shall show that the water shall be treated or blended before it enters the SWP to prevent water quality impacts.
- The project proponent of a Tier 2 proposal should clearly identify and establish that water inflow shall be managed and operated such that poor quality water will be blended with better quality water so that SWP water quality will not be degraded upon acceptable levels as determined by the FG and DWR.
- If a significant water supply deficiency exists and it is recommended by the FG that raw water quality criteria be set aside to ensure adequate supply, such action shall be subject to approval by the DPH.
- The project proponent of a NP inflow program which degrades SWP water quality shall identify mitigation to downstream water contractors for water quality impacts associated with increased water supply or treatment costs.

## **DWR ROLE**

DWR shall seek, as needed, DPH or SWC recommendations on changes or additions to this document governing the NP water quality projects. The FG shall review proposed changes or additions prior to implementation by DWR, as needed.

DWR and or the United States Bureau of Reclamation (for San Luis Canal inflow) shall have ultimate responsibility for approving the water quality of all NP inflow, as well as, the oversight of monitoring and tracking the water quality of operating programs. DWR shall also ensure that the proponents of the NP inflow program perform according to their proposals, and will take appropriate action in the event of non-conformance.

## **Project Proposal Review Process**

Upon receipt of a proposal for PIP, DWR shall review it for adequacy. DWR shall consider all PIPs based upon these guidelines. Review shall take no more than one month after receiving a complete program proposal. If necessary, DWR will convene timely meetings with the FG during the review. At a minimum the review will include

- Examination of all documents and data for completeness of the PIP.
- Notification of the affected Field Divisions, and the FG has been received by DWR.
- Consideration by DWR of comments from all parties before the final decision.
- Upon completion of the review DWR will notify the proponent and FG of the acceptance of the PIP or explain the reason(s) for rejecting it.
- DWR may reconsider a decision on a PIP based upon a recommendation from the FG. Reconsideration by DWR will be on a case-by-case basis.

## **Periodic Review**

DWR may schedule periodic reviews of each operating NP inflow with input from the FG. As part of the review, program proponents shall provide the following information:

- Summary of deliveries to the Aqueduct.
- Water quality monitoring results.
- Proposed changes in the program operation.

The review may result in changes in monitoring and testing required of the program proponent as a result of;

- New constituents being added to the EPA /DPH list of drinking water standards.
- Changes in the maximum contaminant levels for the EPA/DPH list of drinking water standards.
- Identification of new constituents of concern.
- Changes in the water quality provided by the program.
- Changes in constituent background levels in the California Aqueduct.

This procedure shall recognize emerging contaminants and/or those detrimental to agricultural viability as they are identified by the regulatory agencies and shall set appropriate standards for water introduction based upon ambient levels in the California Aqueduct or State Notification Levels. Emerging contaminants are those that may pose significant risk to public health, but as yet do not have an MCL. Currently the Office of Environmental Health Hazard Assessment and the DPH establish Public Health Goals and Notification Levels, respectively. These levels, though not regulated, do provide health-based guidance to water utilities and can require public notification if exceeded.

### **Water Quality Review**

DWR shall track and periodically report to the FG on water quality monitoring results on the SWP from NP water inflow and make all water quality data available to the public upon request.

- DWR shall review analyze and maintain all records of water quality testing conducted by the proponent of the well(s), source(s) and discharge(s) into the SWP.
- DWR shall determine what additional water quality monitoring, if any, is necessary within the SWP to ensure adequate protection of SWP water quality. DWR shall conduct all water quality monitoring within the SWP.
- DWR may prepare periodic reports of NP projects.

### **On-site Surveillance**

The appropriate Field Division within DWR will be responsible for review and approval of all construction activities within the SWP right-of-way. Plans showing the discharge system piping, valves, sampling point, meters and locations must be submitted and approved prior to any construction. In addition, the appropriate Field Division will be responsible for confirmation of all meter readings and water quality monitoring conducted by the proponent.

- Field division staff may visit, inspect, and calibrate meters and measure flow conditions at each source or point of inflow into the SWP.
- Flow meters, sampling ports and anti-siphon valves must be conveniently located near the SWP right-of-way.
- Field division staff may collect water samples at each source or point of discharge into the SWP.
- The appropriate Field Division shall conduct additional water quality monitoring within the SWP, if deemed necessary, to assure compliance with the NP Inflow Criteria.
- DWR shall monitor aqueduct water quality and analyze several “split samples” of the water at the point of introduction into the aqueduct to ensure consistent analytical results.

**Table A1 HISTORICAL WATER QUALITY CONDITIONS 1988 TO 2011 AT O'NEILL FOREBAY OUTLET (mg/L)**

| <b>Parameter</b>     | <b>Mean</b> | <b>Min.</b> | <b>Max.</b> | <b>Std. Dev.</b> |
|----------------------|-------------|-------------|-------------|------------------|
| Aluminum             | 0.03        | 0.01        | 0.527       | 0.05             |
| Antimony             | 0.002       | 0.001*      | 0.005       | 0.002            |
| Arsenic              | 0.002       | 0.001       | 0.004       | 0.001            |
| Barium               | 0.05        | 0.05        | 0.068       | 0.002            |
| Beryllium            | 0.001*      | 0.001*      | 0.001*      | 0.000            |
| Bromide              | 0.22        | 0.04        | 0.54        | 0.16             |
| Cadmium              | 0.003       | 0.001       | 0.005       | 0.002            |
| Chromium             | 0.004       | 0.001       | 0.011       | 0.002            |
| Copper               | 0.004       | 0.001       | 0.028       | 0.003            |
| Fluoride             | 0.1         | 0.1         | 0.5         | 0.1              |
| Iron                 | 0.037       | 0.005       | 0.416       | 0.050            |
| Manganese            | 0.009       | 0.005       | 0.06        | 0.007            |
| Mercury              | 0.001       | 0.0002      | 0.001       | 0.0004           |
| Nickel               | 0.001       | 0.001       | 0.004       | 0.0005           |
| Nitrate              | 2.9         | 0.2         | 8.1         | 1.6              |
| Selenium             | 0.001       | 0.001       | 0.002       | 0.0001           |
| Silver               | 0.003       | 0.001       | 0.005       | 0.002            |
| Sulfate              | 42          | 14          | 99          | 15               |
| Total Organic Carbon | 4.0         | 0.8         | 12.6        | 1.6              |
| Zinc                 | 0.007       | 0.005       | 0.21        | 0.01             |

\*These values represent reporting limits. Actual values would be lower.

**Table A2 O'Neill Forebay Outlet Total Dissolved Solids Criteria by Water Year Classification, 1988-2011 (mg/L)**

| Year Type   | Oct   | Nov   | Dec   | Jan   | Feb   | Mar   | Apr   | May   | Jun   | Jul   | Aug   | Sep   |
|-------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Wet         | 227.2 | 262.5 | 295.4 | 228.9 | 213.8 | 231.2 | 184.4 | 226.5 | 181.5 | 171.4 | 195.7 | 157.3 |
| Near Normal | 317.9 | 324.7 | 351.7 | 295.4 | 268.1 | 302.7 | 270.0 | 285.1 | 230.1 | 211.9 | 170.9 | 202.6 |
| Dry         | 286.4 | 319.6 | 370.0 | 362.0 | 344.2 | 305.2 | 240.4 | 278.2 | 307.3 | 234.8 | 269.0 | 336.6 |
| Critical    | 256.6 | 312.9 | 372.9 | 367.0 | 361.0 | 335.0 | 307.1 | 291.8 | 335.1 | 325.7 | 339.4 | 328.8 |

\* Year type is based on water year classification. Below normal and above normal year types have been combined into one designation called "near normal."

**Table A3 O'Neill Forebay Outlet Bromide Criteria by Water Year Classification, 1988-2011 (mg/L)**

| Year Type   | Oct  | Nov  | Dec  | Jan  | Feb  | Mar  | Apr  | May  | Jun  | Jul  | Aug  | Sep  |
|-------------|------|------|------|------|------|------|------|------|------|------|------|------|
| Wet         | 0.19 | 0.24 | 0.28 | 0.13 | 0.10 | 0.12 | 0.12 | 0.17 | 0.12 | 0.12 | 0.13 | 0.10 |
| Near Normal | 0.31 | 0.31 | 0.34 | 0.21 | 0.15 | 0.15 | 0.18 | 0.22 | 0.15 | 0.15 | 0.14 | 0.19 |
| Dry         | 0.25 | 0.29 | 0.35 | 0.35 | 0.24 | 0.20 | 0.17 | 0.24 | 0.27 | 0.13 | 0.29 | 0.41 |
| Critical    | 0.26 | 0.28 | 0.32 | 0.37 | 0.33 | 0.27 | 0.22 | 0.22 | 0.28 | 0.28 | 0.32 | 0.37 |

\* Year type is based on water year classification. Below normal and above normal year types have been combined into one designation called "near normal."

**Table A4 O'Neill Forebay Outlet Total Organic Carbon Criteria by Water Year Classification, 1988-2011 (mg/L)**

| Year Type*  | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep |
|-------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Wet         | 2.8 | 2.9 | 3.9 | 5.2 | 4.8 | 3.8 | 3.9 | 3.4 | 3.1 | 3.2 | 3.1 | 2.7 |
| Near Normal | 3.7 | 4.1 | 4.0 | 7.0 | 6.3 | 5.6 | 4.7 | 4.4 | 4.0 | 3.3 | 3.3 | 3.4 |
| Dry         | 3.0 | 3.0 | 4.0 | 5.7 | 4.8 | 5.7 | 4.5 | 3.6 | 3.7 | 2.9 | 2.9 | 2.7 |
| Critical    | 2.8 | 3.1 | 3.3 | 4.9 | 6.0 | 5.7 | 4.7 | 4.0 | 3.8 | 3.9 | 4.0 | 3.5 |

\* Year type is based on water year classification. Below normal and above normal year types have been combined into one designation called "near normal."

## Appendix B. Monitoring of WWD Lateral 7 by Reclamation

Westlands Water District can pump water from the Mendota Pool to the San Luis Canal through Lateral 7. Reclamation will require special monitoring of this water while it is being pumped from WWD Lateral 7 into the canal. This will consist of weekly field measurements of salinity and turbidity, and collection of grab samples to measure a short list of constituents. After four consecutive weeks, the samples should be collected monthly for the duration of pumping.


Reclamation will ask for a full Title 22 analysis of the water in the lateral each year while pumping from the lateral into the canal occurs.

This monitoring may be modified by Reclamation to change the frequency of measurements and the range of parameters. Westlands will pay for the costs of sampling and analysis for this special monitoring program.

Reclamation may take field measurements and other samples of water from the canal upstream and downstream of the Lateral 7 discharge. Reclamation will pay for the sampling and analytical costs of these instream samples.

### Location of Monitoring Sites

|  | Northing       | Westing         |
|--|----------------|-----------------|
| San Luis Canal MP 113.82<br>Lincoln Ave bridge (upstream site) | 36o38'50.72" N | 120o31'26.37" W |
| WWD Lateral 7 at Adams Avenue                                  | 36o37'57.22" N | 120o20'37.77" W |
| San Luis Canal MP 115.43L<br>WWD Lateral 7 turnout structure   | 36o37'55.55" N | 120o20'33.36" W |
| San Luis Canal MP 117.47<br>Manning Ave (downstream site)      | 36o36'43.68" N | 120o29'22.54" W |




San Luis Canal Milepost 113.82 – Lincoln Ave bridge (upstream sampling site)






Westlands Water District Lateral 7 at Adams Avenue



San Luis Canal MP 115.43L WWD Lateral 7 turnout





San Luis Canal Milepost 117.47 – Manning Avenue (downstream sampling site)

# Appendix C: Cultural Resources Determination

**CULTURAL RESOURCES COMPLIANCE**  
**Division of Environmental Affairs**  
**Cultural Resources Branch (MP-153)**

**MP-153 Tracking Number:** 17-SCAO-212

**Project Name:** Westlands Water District 5-year Warren Act Contract for Kings River Flood Flows in the San Luis Canal

**NEPA Document:** EA-17-023

**NEPA Contact:** Mary (Kate) Connor, Natural Resource Specialist

**MP-153 Cultural Resources Reviewer:** BranDee Bruce, Architectural Historian

**Date:** June 30, 2017

---

Reclamation proposes to approve a five year Warren Act contract with the Westlands Water District (WWD) for the conveyance of up to 50,000 acre feet (AF) per year of non-CVP water in the San Luis Canal beginning July 1, 2017 through June 30, 2022. The non-CVP water will be introduced at milepost (MP) 113.00 (Lateral 6-1) and/or MP 115.43 (Lateral 7-1), the water will be diverted into existing WWD turnouts (63 total), plus the Pleasant Valley Canal system and any approved existing temporary agricultural diversion used within the WWD Service Area. This proposed action is strictly a water transfer action and will not involve any new construction or ground-disturbing activities.

Reclamation determined that the proposed action is the type of undertaking that does not have the potential to cause effects on historic properties, should such properties be present, pursuant to 36 CFR § 800.3(a)(1). As such, Reclamation has no further obligations under 54 U.S.C. § 306108, commonly known as Section 106 of the National Historic Preservation Act (NHPA).

Reclamation cultural resources staff has reviewed the draft Environmental Assessment for this project and agrees the current language in the EA is sufficient for cultural resources analysis. No additional language will be provided.

This document conveys the completion of the cultural resources review and NHPA Section 106 process for this undertaking. The proposed action would have no impacts on cultural resources. Please retain a copy of this document with the administrative record for the proposed action. Should the proposed action change, additional review under Section 106, possibly including consultation with the State Historic Preservation Officer, may be required.

# Appendix D: Water Quality Report Summary

US Bureau of Reclamation

Westlands Water District - 2017 Diversion of Kings River Flood water through WWD Lateral 7 to the San Luis Canal.

Sample: Kings River Conveyance 7-2 Pumping Plant

Location: Lateral 7 intake canal, South Merced and Adams Avenue, near Tranquillity.  
36.632570, -120.642319

| Sample date | Lab  | Method  | Bromide<br>mg/L | Chloride<br>mg/L | Conductivity<br>umhos/cm | Nitrate<br>mg/L | Sulfate<br>mg/L | TDS<br>mg/L | Arsenic<br>ug/L | Boron<br>mg/L | Manganese<br>mg/L | Selenium<br>ug/L | pH<br>units | EC<br>uS/cm | DO<br>mg/L | Turbidity<br>NTU | Temperature<br>degrees C |
|-------------|------|---------|-----------------|------------------|--------------------------|-----------------|-----------------|-------------|-----------------|---------------|-------------------|------------------|-------------|-------------|------------|------------------|--------------------------|
|             |      | 300.1   | 300             | SM2510b          | 300                      | 300             | SM2450c         | 200.8       | 200.7           | 200.7         | 200.8             |                  |             |             |            |                  |                          |
|             |      | MCL     | TBD             | 250              | 1,692                    | 45              | 600             | 1,100       | 10              | 2             | 0.05              | 50/2(*)          |             |             |            |                  |                          |
|             |      | RL      | 0.0050          | 1.0              | 1.0                      | 1.0             | 1.0             | 5.0         | 2.0             | 0.10          | 0.010             | 2.0              |             |             |            |                  |                          |
|             |      | Units   | mg/L            | mg/L             | umhos/cm                 | mg/L            | mg/L            | mg/L        | ug/L            | mg/L          | mg/L              | ug/L             | units       | uS/cm       | mg/L       | NTU              | degrees C                |
| 3/9/2017    | BSK  | A7C0974 | 0.045           | 1.1              | 71                       | 1.6             | 3.0             | 56          | <2.0            | <0.10         | 0.038             | <2.0             |             |             |            |                  |                          |
| 3/16/2017   | BSK  | A7C1743 | <0.0050         | 1.1              | 73                       | 1.4             | 2.9             | 55          | <2.0            | <0.10         | 0.033             | <2.0             |             |             |            |                  |                          |
| 3/23/2017   | BSK  | A7C2309 | <0.0050         | 1.1              | 63                       | 1.6             | 2.7             | 50          | <2.0            | <0.10         | 0.039             | 2.8 (*)          |             |             |            |                  |                          |
| 3/30/2017   | BSK  | A7C2877 | <0.0050         | 1.0              | 62                       | 1.6             | 2.7             | 56          | <2.0            | <0.10         | 0.061             | <2.0             |             |             |            |                  |                          |
| 4/20/2017   | BSK  | A7D1921 | <0.0050         | <1.0             | 55                       | <1.0            | 2.1             | 50          | <2.0            | <0.10         | 0.041             | <2.0             |             |             |            |                  |                          |
| 4/20/2017   | USBR | Field   |                 |                  |                          |                 |                 |             |                 |               |                   |                  | 7.17        | 59          | 10.61      | NA               |                          |
| 5/18/2017   | BSK  | A7E2151 | <0.0050         | <1.0             | 39                       | <1.0            | 1.2             | 36          | <2.0            | <0.10         | 0.040             | <2.0             | 7.92        | 157         | 8.33       | 46.8             | 24.4                     |
| 6/1/2017    | USBR | Field   |                 |                  |                          |                 |                 |             |                 |               |                   |                  |             |             |            |                  |                          |
| 6/15/2017   | BSK  | A7F1705 | <0.0050         | <1.0             | 38                       | <1.0            | 1.8             | 46          | <2.0            | <0.10         | 0.037             | <2.0             | 7.12        | 42          | 8.08       | 70.2             | 24.03                    |
| 6/22/2017   | USBR | Field   |                 |                  |                          |                 |                 |             |                 |               |                   |                  |             |             |            |                  |                          |

Schedule: Weekly for four consecutive weeks, once per month for the duration of all pumping from Lateral 7 into the San Luis Canal

Constituents: Table 5b: Arsenic, Boron, Bromide, Nitrate (as NO3), Selenium, Chloride, Manganese, Specific Conductance, Sulfate, and Total Dissolved Solids.

Notes: (\*) Selenium objective: Title 22 = 50 ug/L; Basin Plan for Grasslands wetlands channels = 2 ug/L monthly average.  
Lateral 7 is not a Grasslands wetlands channel.

Sample: San Luis Canal Milepost 117.47 Manning Avenue

| Sample date | Lab  | Units | Bromide<br>mg/L | Chloride<br>mg/L | Conductivity<br>umhos/cm | Nitrate<br>mg/L | Sulfate<br>mg/L | TDS<br>mg/L | Arsenic<br>ug/L | Boron<br>mg/L | Manganese<br>mg/L | Selenium<br>ug/L | pH<br>units | EC<br>uS/cm | DO<br>mg/L | Turbidity<br>NTU | Temperature<br>degrees C |
|-------------|------|-------|-----------------|------------------|--------------------------|-----------------|-----------------|-------------|-----------------|---------------|-------------------|------------------|-------------|-------------|------------|------------------|--------------------------|
| 6/22/2017   | USBR | Field |                 |                  |                          |                 |                 |             |                 |               |                   |                  | 7.42        | 134         | 8.27       | 21.8             | 25.05                    |

