


Hydropower Resource Update

Jerry Wilhite
TWG Meeting
April 11, 2024



Outline

- Hydropower elements
- CRSP generation 1971-2023
- WY 2023 CRSP generation
- Glen Canyon Dam generation
- New rate action
- DSA
- Experiments
- Basin fund
- Current activities




Hydropower Elements

- Capacity
- Transmission
- Resource adequacy
- Emissions
- Pricing (LMPs)
- Electrical emergencies
- Rates (wholesale and retail)
- Non-use value
- Tribal benefits
- Ancillary services
- Availability of replacement power
- Basin fund
- Amount and value of generation




Water Year 1971-2023 Generation




WY23 Generation (cont.)


Total Annual Generation and Composite Rate 2001 - 2023



Glen Canyon Dam Generation WYs 23-24




Glen Canyon Dam Annual Generation 1971-2024




New Rate Action

- WAPA-199
 - Implemented December 2021
 - Avoid a 50% rate increase by reducing purchase power
 - Two-year rate
 - Increased energy rate from 12.19 mills/kWh to 12.36 mills/kWh
 - Increased capacity rate from \$4.85 to \$5.25/kW-month
 - Deliverable Sales Amount (DSA) concept established
- WAPA-206
 - Implemented January 1, 2024
 - Five-year rate
 - No changes to rates
 - Continued DSA implementation




What is DSA?

- Deliverable Sales Amount
- Forecasted quarterly
 - Aug, Nov, Feb, May
- Firm to forecasted energy and capacity amount.
- Energy above forecasted amount offered to customers or sold to the market.
- No change to minimum schedule requirement.
- Example December 2023
 - Purchased about \$0.616 million
 - 25 GWh
 - Avoided \$5.4 million in firm purchases
 - 109 GWh




DSA Performance

Monthly and Cumulative Net Position Relative to DSA




SHP vs DSA Purchases December 2021 - September 2023



Avoided cost \approx \$211 million



Water Year 2023 Monthly and Cumulative Net Position Relative to DSA



Reservoir Elevation Matters

- Higher reservoir elevation increases unit efficiency in converting water flow into energy
- When the reservoir is full (3,700 ft), it takes about 1.9 acre-feet of water to generate 1 MWh or energy
- At 3,600 ft, it takes about 2.3 acre-feet to generate 1 MWh
- At 3,500 ft that number rises to 2.9 acre feet to generate 1 MWh

Water year	Annual volume (maf)	Avg elevation	Energy produced (GWh)	Percent difference
2023	8.491	3,545.61	3,321	NA
1991	8.491	3,632.41	3,946	19%
1985	8.491	3,687.85	4,390	32%
2024	8.491	3,569.59	3,570	7%



Experiments

Experiment	Estimated cost (\$M)	Observed cost (\$M)	Observed - Estimated (\$M)	Observed percent difference
High Flow Experiments (HFEs)				
2012*		1.92		
2013	1.74	2.59	0.85	49.0%
2014	1.75	2.10	0.35	20.1%
2016	1.40	1.15	-0.25	-17.9%
2018	0.92	1.30	0.38	40.7%
2023	1.48	**	**	**
Macroinvertebrate Flows				
2018	0.34	0.17	-0.17	-50.6%
2019	0.33	0.33	-0.005	-1.5%
2020	0.41	0.94	0.533	130.6%
2022	1.40	1.15	-0.247	-17.6%


*Includes cost of fall steady flow

**Cost estimate not complete




Basin Fund


Where is Basin Fund Cash Going?



Basin Fund Balances (End of FY)




Basin Fund Returns



Future CRSP Power Scheduling

- Aridification/drought is causing reductions in generation at Glen Canyon Dam
- Addition of non-dispatchable renewable resources is changing the way customers schedule CRSP power.
- Customers are increasingly scheduling CRSP power to meet “net demand” (retail demand minus solar/wind power)
- Can WAPA meet customer load with the anticipated changes in customer schedules?




Operating Criteria and Agreements Considered

- Environmental Criteria

- Minimum release rate (GC, FG)
- Maximum ramp up/down (GC, FG)
- Maximum 24-hr change (GC)

- Unwritten Agreements

- Same volume of water release each day of the week (GC)
- 85% rule for Saturday and Sunday (GC)
- Simple/double cycle pattern (GC, FG)




Phase 1 Results




	Option 1	Option 2	Option 3	Option 4
Purchases/sales allowed	✓			
Operating criteria strictly enforced	✓	✓		✓
Unwritten agreements strictly enforced	✓			
Keep current load scheduling rules for CRSP customer	✓	✓	✓	
Can CRSP resources meet load?	Yes	Most of the time	Yes	Yes

Constraint exceedance frequency (%)



Plexos Reconfiguration

- PLEXOS
 - WECC-wide model
 - Simulates operation of electric power system hourly or subhourly
- GCD is small when considered in the context of the entire western interconnection.
- NREL worked with the Plexos developers to reduce the WI footprint down to balancing authorities that are impacted by Glen Canyon Dam generation.
- Only generators that could reasonably respond to a reduction/loss of GC generation were considered as sources of replacement power.



Phase 2

Objectives:

- Determine the consequences of the loss of power generation at GCD and to model the feasibility of mitigating the loss of GCD power through the joint/companion (hybrid) operation of GCD with another renewable generator.

Research questions:

- What is the capability of GCD to provide capacity for ancillary services at reduced capacity and generation?
- What are the impacts to the Salt River Project exchange?
- Is replacement energy available?
- Is the existing transmission grid capacity capable of getting replacement energy (if available) to federal delivery points?
- Would the need to transmit replacement power “stress” regional transmission lines?
- Are reserves and regulating capacity available elsewhere to support grid reliability?
- Could the joint or hybrid operation of a utility-sized solar generating station mitigate the loss of GCD energy?



GTMax Update

- Generation and Transmission Maximization model
 - Models flow of electricity, water, and money
 - Produces “optimal” hourly generation patterns for 1 week each month
- GTMax SuperLite
 - Same mathematical formulation
 - Allowed for multiple scenario analysis over multiple years
 - Multithread
- Used for short and long-term planning
 - Daily patterns
 - Purchase power estimates
 - Impacts of operational changes
 - Resource availability (energy and capacity)



GTMax Update

- Analyses have become much larger and more complex (e.g., post-2026 EIS) exceeding Excel's capabilities
- Same hydropower scheduling logic as current GTMax SL
- Single Excel-based user interface with a Python-based algorithm and solver
 - GTMax SL used an ensemble of spreadsheets with Excel formula-based algorithm and a Lingo-based solver
- Faster (~100x) run time with native multi-threading capability
 - GTMax SL took 10s-10min per run with the need for an add-on tool to use multithreading
- Case study size only limited by the computer RAM (~5M runs on a standard machine)
 - GTMax SL was limited by Excel spreadsheet row limit



Post-2026

- Hydropower modelling to begin April 2024
 - Argonne National Lab
- 1,200 traces over 30+ years
 - 432,000 months per trace
 - Over 315 million hours per trace
- Challenges
 - Number of traces
 - Modelling time
 - Data volume
 - Difficult to anticipate changes in the electric system over 30 years
 - scheduling
 - Energy pricing



Jerry Wilhite

wilhite@wapa.gov

(970) 240-6561



www.wapa.gov